
State Environmental Policy Act
DETERMINATION OF SEPA EXEMPT - SWCAA 24-017

Description of proposal:

ADP Application CL-3264: The proponent has applied for a permit to remove Stage II vapor recovery equipment at an existing gas station. Stage II vapor recovery equipment collects displaced vapors from vehicle gas tanks during refueling and returns the vapors to the gas station storage tank. Stage II vapor recovery is becoming increasingly redundant with the increased fleet penetration of on-board carbon canisters in individual vehicles. This permitting action may result in increased gasoline vapor emissions in the short term but will reduce gasoline vapor emissions in the long term as the percentage of vehicles equipped with on-board carbon canisters increases. This permitting action is not expected to have any impact on any other element of the environment including traffic, noise, glare, housing, or recreation opportunities.

Proponent:

Safeway Fueling Station #1519

Location of proposal, including street address if any:

13719 SE Mill Plain Blvd., Vancouver, WA 98683

Lead agency: Southwest Clean Air Agency

The lead agency for this proposal has determined that the proposed project is exempt from SEPA under WAC 197-11-800(3) as follows: "The repair, remodeling, maintenance, or minor alteration of existing private or public structures, facilities or equipment, including utilities, recreation, and transportation facilities involving no material expansions or changes in use beyond that previously existing;" The proposed project is identified as maintenance of existing equipment and as such it does not have a probable significant impact on the environment. Neither an environmental checklist nor an environmental impact statement (EIS) is required under RCW 43.21C.030(2)(c). This decision was made by the lead agency after review of the proponent's proposal and the information on file with the lead agency. This information is available to the public on request.

This project/permitting action by SWCAA is SEPA exempt.


Responsible official: Clinton Lamoreaux, P.E.

Position/title: Chief Engineer

Address: Southwest Clean Air Agency
11815 NE 99th St, Suite 1294
Vancouver, WA 98682-2322

Phone: (360) 574-3058 ext. 131

Signature: _____



Date: April 10, 2024

