





Atlas Labs

Name / Company Name: ServiceMaster by JTS	Phone: (360) 425-3331
Contact Email: mail@servicemasterjts.com	
Job Name: Shelley	Job/Project #123-do46
Job/Project Location: 15900 NE 183 rd St + brush near tip tra 98606	

Please check box that applies

X	Abestos PLM
	Lead Paint
	Other

[illegible]

Client Sign Here: 		Date: 10/17/23	Time: 2:4
Atlas: Accepted By: Kelly Katona		Date: 10.18.2023	Time: 11:55am
Credit Card:	Cash:	Check #	Amount \$
Lab Results Completed By: 		Date Sent Out: 10/18/23	(Email)/Fax/Mail

*Atlas charges a per sample fee and not by layer. One sample fee equals four layers. Additional layers will result in an additional sample fee.



Batch # 2022 *

22-928901

Analysis Date *

10/18/2023

Project #

L23-0646

Analyst *

Crossland Kapaun

Name / Company *

ServiceMaster by JTS

Project Name

Shelley

PO #

Project Location *

15900 NE 183rd St., Brush
Prairie, WA 98606

Turnaround Time *

Rush

Asbestos Analysis of Bulk Material by Polarized Light Microscopy

Sample*	Layer*	Description*	Non Asbestos*	Asbestos Type*	Asbestos %*
1	1	Drywall (White) - Bath	Cellulose	None Present	N/D
1	2	Wallpaper (Beige / Green) - Bath	Cellulose	None Present	N/D
2	1	Vinyl (Brown / Grey) - Bath	Cellulose	Chrysotile	25%
2	2	Mastic (Yellow) - Bath	Cellulose	Chrysotile	2%

To Be Filled by the Technician

Technician *

CK

Atlas Laboratories maintains liability to cost of analysis. This report relates only to the samples reported and may not be reproduced, except in full without written permission by Atlas. Atlas bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. This report must not be used by the client to claim product certification, approval or endorsement by NVLAP, NIST, NIOSH or any other agency of the federal government. Non-friable organically bound materials present a problem matrix and therefore Atlas recommends gravimetric reduction prior to analysis. Samples received in good condition unless otherwise noted. Transmission Electron Microscopy asbestos identification and lead paint analysis will be available and performed by laboratories by proxy. Original analysis documents are available upon request of the client.

