



11815 NE 99th Street, Suite 1294  
Vancouver, WA 98662  
Voice: 360-574-3058  
Fax: 360-576-0925  
Web: <https://www.swcleanair.gov>  
Email: [Tina@swcleanair.gov](mailto:Tina@swcleanair.gov)

## Notice of Intent to Remove Asbestos

Case #: 24-138

Amendment: 0

Date Received: 3/6/2024

Date Paid: 3/6/2024

SWCAA Fee: \$369.00

Receipt #: 152389796

**This notification MUST be present at all times at the asbestos project sit**

Quantity to be removed: 900 Square Feet 0 Linear Feet

Workshift days: M T W

Project starting date: 3/18/2024 Project Completion date: 3/20/2024

Workshift hours: 8:00 am - 4:30pm

Site Name: Genteel Investments ACM

Site address: 4801 NE 68th St.

Location of Asbestos: Flooring

City/State/Zip: Vancouver WA 98661

☐ Demolition of Structure (Notification of Demolition required)

County: CLARK COUNTY

☒ Asbestos survey conducted?

No survey reason:

AHERA Inspector: Emily Weiss

Certification #: BI/NES-07-26-23-02

### Material to be Removed:

- |   |  |                              |   |  |                                    |
|---|--|------------------------------|---|--|------------------------------------|
| <input type="checkbox"/> Fireproofing                           | <input type="checkbox"/> Popcorn Ceiling     | <input type="checkbox"/> CAB | <input checked="" type="checkbox"/> Sheet Vinyl | <input type="checkbox"/> Boiler Insulation | <input type="checkbox"/> Duct Tape |
| <input type="checkbox"/> Duct Paper                             | <input type="checkbox"/> Mag Pipe Insulation |                              | <input type="checkbox"/> Air Cell               | <input type="checkbox"/> CA Pipe           | <input type="checkbox"/> VAT       |
| <input checked="" type="checkbox"/> Other Floor Tile and Mastic |  |                              |   |  |                                    |

### Control Methods:

- |   |                                    |   |                                       |   |  |
|---|------------------------------------|---|---------------------------------------|---|--|
| <input checked="" type="checkbox"/> N.P Enclosure                                 | <input type="checkbox"/> Glove Bag | <input type="checkbox"/> Mini Enclosure | <input type="checkbox"/> Wrap and Cut | <input checked="" type="checkbox"/> Water | <input checked="" type="checkbox"/> HEPA Vac |
| <input checked="" type="checkbox"/> Other Manual Methods, PAPR, Critical Barriers |                                    |   |                                       |   |  |

Asbestos Contractor: 3 Kings Environmental Inc.

Phone: 253-750-4143

Mailing Address: PO Box 280, Battle Ground, WA, 98604

Email: [jhawks@3kingsinc.com](mailto:jhawks@3kingsinc.com)

Certification ##: ABCN00001318

Supervisor: Emily Weiss

Phone: 253-750-4143

Property Owner: Genteel Investments LLC

Phone: 360-694-0727

Mailing Address: PO Box 1434, Vancouver WA 98668

Asbestos Disposal Site: Wasco County Landfill: 2550 Steele Rd, The Dalles, OR, 97058-

**I DO HEREBY CERTIFY THAT THE INFORMATION CONTAINED IN THIS NOTIFICATION IS,  
TO THE BEST OF MY KNOWLEDGE, ACCURATE AND COMPLETE.**

Submitter Name: Kristine Bantz

Representing: 3 Kings Environmental

Submitter Title: Office Admin

Date Submitted: 3/6/2024

Reviewed by SWCAA: Danielle Kreps

*Danielle Kreps*

☒ Approved



11815 NE 99th Street, Suite 1294  
Vancouver, WA 98662  
Voice: 360-574-3058  
Fax: 360-576-0925  
Web: <https://www.swcleanair.gov>  
Email: [Tina@swcleanair.gov](mailto:Tina@swcleanair.gov)

## Notice of Intent to Remove Asbestos

Case #: 24-138

Amendment: 0

Date Received: 3/6/2024

Date Paid: 3/6/2024

SWCAA Fee: \$369.00

Receipt #: 152389796

**This notification MUST be present at all times at the asbestos project sit**



3 Kings Environmental, Inc.

# Asbestos Containing Materials Inspection

Good Faith Inspection

December 6, 2023

Prepared For: Genteel Investments, Inc.  
C/O Roy Heikkala  
PO Box 1434  
Vancouver, WA 98668

Project: 4801 NE 68<sup>th</sup> Street  
Vancouver, WA 98668

RE: Good Faith Asbestos Survey

### **FRONT OF STRUCTURE**



# INSPECTION REPORT

## **BACKGROUND**

On November 20, 2023, 3 Kings Environmental, Inc. performed a Good Faith Asbestos Inspection of the above-mentioned project to determine the presence of asbestos containing materials (ACMs). The intent of this inspection is to ensure that the property owner is in compliance with the regulatory requirements for the identification of ACMs prior to any demolition or renovation activities.

## **BUILDING DESCRIPTION**

The residential structure was a single-story building with attached carport. The majority of the building was on a concrete foundation with sections on wood. Total building square footage is approximate 1,000 SF, approximate date of construction was 1961.

### **Interior Finishes:**

The interior of the building included drywall with and without texture. Flooring materials consisted of floor tile and mastic throughout, sheet vinyl and laminate. There were also suspended ceiling tiles located in the bathroom.

### **Exterior Finishes:**

The exterior of the building was wood siding with composition roofing.

## **SAMPLING PROCESS**

All accessible areas of the specific work area were sampled during the inspection. Inaccessible areas are those defined as requiring select demolition, fall protection, repair to the structure i.e. weather protection or water proofing or are considered a confined space entry. If during the course of asbestos abatement or demolition suspect materials are discovered that are not identified in this report stop work immediately. These materials need to be treated as asbestos-containing until the material can be tested by an AHERA Building Inspector and determined otherwise.

Suspect materials were collected by an AHERA certified building inspector. Samples are then given a unique identification number. Sample information such as type of material and its locations are then placed on the chain of custody that accompany the samples to the testing laboratory. Once the samples are delivered to an asbestos laboratory for analysis. Samples are analyzed by polarized light microscopy (PLM) with dispersion staining in accordance with USEPA 600/M-82/020, which has a reliable limit of quantification of one percent asbestos by volume.

Samples were collected following EPA guidelines. The suspect materials are broken down into three categories: Surfacing Materials, Thermal System Insulation, and Miscellaneous Materials. Each of these categories have a set of guideline that were followed that include the number of samples required for that particular category based on the quantity of the material, how the material was applied and what was the intent of the material. All these factors are accounted for during the time of inspection.

## **AHERA Certified Building Inspector**

Certified AHERA Building Inspector was Emily Weiss  
Certification # BI-NES-07262302, Expiration July 26, 2024

## **SURVEY FINDINGS**

Materials found to contain asbestos in concentrations greater than one percent (>1%) as part of this investigation and estimated quantities for removal:

Sample #	Material Description	Sample Location	Friability / Condition	Lab Result	Quantity
10, 11	Beige Sheet Vinyl over Floor Tile & Black Mastic under Brown Laminate Flooring	Kitchen	NF / Good	25% Chrysotile Sheet Vinyl, 4% Chrysotile Floor Tile Only / Mastic NAD	132 SF
12, 13	Beige 9x9 Vinyl Floor Tile & Mastic	Bedroom 2 & Living Room Front Entry	NF / Good	4% Chrysotile (Tile only)	738 SF
16, 17	Beige 9x9 Vinyl Floor Tile & Brown Mastic	Bathroom	NF / Good	4% Chrysotile (Tile only)	30 SF

	10, 11 – Beige Sheet Vinyl over Floor Tile & Black Mastic – Floor of Kitchen.
	12 – Vinyl Floor Tile & Mastic – Floor of Bedroom 2.



			13 – Vinyl Floor Tile & Mastic – Living Room Front Entry.
			16, 17 - Vinyl Floor Tile & Brown Mastic – Floor of Bathroom.

The following is a summary of all the suspect bulk asbestos sampled during the inspection.

Sample #	Material Description & Location	Friability	Material Category	Lab Result
01	Ceiling Texture – Living Room front Entrance	F	S	NAD
02	Ceiling Texture, Drywall & Joint Compound – Adjacent Sliding Door	F	S	NAD
03	Ceiling Texture, Drywall & Joint Compound – Hall Ceiling	F	S	NAD
04	Drywall & Joint Compound – Bedroom 1 (Composite Analysis of Wallboard System)	NF	M	< 1% Chrysotile Drywall NAD
05	Stipple Texture – Kitchen Ceiling	F	S	NAD
06	Stipple Texture – Kitchen Ceiling	F	S	NAD
07	Stipple Texture – Kitchen Ceiling	F	S	NAD
08	Drywall & Joint Compound, Light Stipple Texture – Kitchen Wall (Composite Analysis of Wallboard System)	F	S	< 1% Chrysotile, Drywall & Texture NAD
09	Drywall & Joint Compound, Light Stipple Texture – Kitchen Wall	F	S	NAD
10	Beige Sheet Vinyl over Vinyl Floor Tile, Black Mastic – Kitchen	NF	M	4-25% Chrysotile / Mastic NAD
11	Beige Sheet Vinyl over Vinyl Floor Tile, Black Mastic – Kitchen	NF	M	PACM



12	Vinyl Floor Tile and Mastic – Bedroom 2	NF	M	4% Chrysotile (Tile only)
13	Vinyl Floor Tile and Mastic – Bedroom 2	NF	M	PACM
14	Beige Sheet Vinyl Flooring - Bathroom Floor	NF	M	NAD
15	Beige Sheet Vinyl Flooring - Bathroom Floor	NF	M	NAD
16	Vinyl Floor Tile and Brown Mastic under Sheet Vinyl – Bathroom	NF	M	4% Chrysotile (Tile only)
17	Vinyl Floor Tile and Brown Mastic under Sheet Vinyl – Bathroom	NF	M	PACM
18	Cove Base and Adhesive – Kitchen	NF	M	NAD
19	Cove Base and Adhesive – Kitchen	NF	M	NAD
20	Brick and Mortar – Living Room	NF	M	NAD
21	Brick and Mortar – Living Room	NF	M	NAD
22	Ceiling Tiles – Bathroom	NF	M	NAD
23	Ceiling Tiles – Bathroom	NF	M	NAD
24	Shower Surround Mastic – Bathroom	NF	M	NAD
25	Shower Surround Mastic – Bathroom	NF	M	NAD
26	Bottom Layer Composition Roof - White	NF	M	NAD
27	Bottom Layer Composition Roof - White	NF	M	NAD
28	Roof Felt – Middle Layer	NF	M	NAD
29	Roof Felt – Middle Layer	NF	M	NAD
30	Top Layer Composition Roof - Black	NF	M	NAD
31	Top Layer Composition Roof - Black	NF	M	NAD

**Legend:**

NAD – No Asbestos Detected  
F – Friable (can be pulverized by hand pressure)  
NF – Non-Friable  
PACM – Presumed Asbestos Containing Material

**Category:**

S – Surfacing Material  
TSI – Thermal System Insulation  
M – Miscellaneous Material

## **ADDITIONAL OBSERVATIONS**

### **Lead Paint and Other Metals**

Lead-based paint was not sampled as part of this survey. Based on the age of the structure lead-based paints should be assumed.

Lead safe work practices and appropriate precautions should be utilized during all work impacting painted surfaces.

### **Microbial Growth**

Water damage and potential microbial growth were not observed as part of this sampling. Appropriate precautions should be utilized during work.

### **PCBs, Mercury Bulbs and Mercury Thermostats**

PCBs, Mercury Bulbs and Mercury Thermostats were not tested or examined as part of this survey. Appropriate precautions should be utilized during work.

### **Inaccessible Components**

No inaccessible components spaces were observed at the time of the inspection.

## **RESULTS AND RECOMMENDATIONS**

Of the thirty-one (31) suspect bulk materials sampled three (3) tested positive for asbestos with a concentration greater than 1%. Three additional samples are noted as presumed asbestos containing materials (PACM) as they were designated for positive-stop. Two additional samples were noted as positive for asbestos. Additional composite analysis was performed on the wallboard systems on November 30, 2023 resulting in asbestos concentrations less than 1%.

3 Kings Environmental, Inc. recommends that any ACM or PACM to be impacted during the course of the renovation or demolition be removed by a licensed, bonded, and insured asbestos abatement firm. Removal and disposal of asbestos containing materials should only be performed by certified firms following all local, state, and federal guidelines. Should materials not noted in this report be discovered during the course of the work, stop all demolition and have the newly discovered materials tested for asbestos or treat the materials as an asbestos containing material. Be sure to notify the governing authorities and clean-air agencies prior to disturbing materials over the recordable limits.

The conclusions/ recommendations of the report are professional opinions based solely on visual observations and interpretation of sample results from our third party laboratory. Re-use of this document for other than its intended purpose are at the sole risk of said user. 3 kings Environmental, Inc. cannot be held responsible for the interpretation by others of the data contained in this report as site conditions or regulations may have changed. 3 Kings Environmental makes no warranty, expressed or implied for information found in this report.

If you have any questions regarding this asbestos survey/inspection report, please contact me at (360) 907-4510, or email: [eweiss@3kingsinc.com](mailto:eweiss@3kingsinc.com)

Respectfully submitted,  
**3 Kings Environmental, Inc.**

A handwritten signature in black ink that reads 'Emily Weiss'.

Emily Weiss  
Certified AHERA Building Inspector

# LAB RESULTS



**The Identification Specialists**

Analysis Report  
prepared for  
3 Kings Environmental Inc.

**Report Date: 11/30/2023**

**Project Name: GI - 4801 Ph.1 & ACM-Amended Report JT**

**Project #: 223143**

**SanAir ID#: 23064683**



NVLAP LAB CODE 200870-0

10501 Trade Court | North Chesterfield, Virginia 23236  
888.895.1177 | 804.897.1177 | fax: 804.897.0070 | [IAQ@SanAir.com](mailto:IAQ@SanAir.com) | [SanAir.com](http://SanAir.com)



SanAir ID Number  
**23064683**  
FINAL REPORT  
11/30/2023 11:42:51 AM

**Name:** 3 Kings Environmental Inc.  
**Address:** PO Box 280  
Battle Ground, WA 98604  
**Phone:** 360-666-5464

**Project Number:** 223143  
**P.O. Number:** 12023-277  
**Project Name:** GI - 4801 Ph.1 & ACM-Amended Report JT  
**Collected Date:** 11/20/2023  
**Received Date:** 11/22/2023 10:10:00 AM

Dear Emily Weiss,

We at SanAir would like to thank you for the work you recently submitted. The 31 sample(s) were received on Wednesday, November 22, 2023 via UPS. The final report(s) is enclosed for the following sample(s): 01, 02, 03, 04, 05, 06, 07, 08, 09, 10, 11, 12, 13, 14, 15, 16, 17, 18, 19, 20, 21, 22, 23, 24, 25, 26, 27, 28, 29, 30, 31.

These results only pertain to this job and should not be used in the interpretation of any other job. This report is only complete in its entirety. Refer to the listing below of the pages included in a complete final report.

Sincerely,

A handwritten signature in black ink that reads "Sandra Sobrino". The signature is fluid and cursive.

Sandra Sobrino  
Asbestos & Materials Laboratory Manager  
SanAir Technologies Laboratory

**Final Report Includes:**

- Cover Letter
- Analysis Pages
- Disclaimers and Additional Information

**Sample conditions:**

- 31 samples in Good condition.



SanAir ID Number  
**23064683**  
FINAL REPORT  
11/30/2023 11:42:51 AM

**Name:** 3 Kings Environmental Inc.  
**Address:** PO Box 280  
Battle Ground, WA 98604  
**Phone:** 360-666-5464

**Project Number:** 223143  
**P.O. Number:** 12023-277  
**Project Name:** GI - 4801 Ph.1 & ACM-Amended Report JT  
**Collected Date:** 11/20/2023  
**Received Date:** 11/22/2023 10:10:00 AM

Analyst: Childress, Susan

### Asbestos Bulk PLM EPA 600/R-93/116

SanAir ID / Description	Stereoscopic	Components		Asbestos Fibers
	Appearance	% Fibrous	% Non-fibrous	
01 / 23064683-001 Ceiling Texture/Living Room	White Non-Fibrous Homogeneous		100% Other	None Detected
02 / 23064683-002 Ceiling Drywall & Joint Compound / Adj Siding, Drywall	White Non-Fibrous Homogeneous	10% Cellulose	90% Other	None Detected
02 / 23064683-002 Ceiling Drywall & Joint Compound / Adj Siding, Joint Compound	White Non-Fibrous Homogeneous		100% Other	None Detected
03 / 23064683-003 Ceiling Drywall & Joint Compound / Hall Ceiling, Drywall	White Non-Fibrous Homogeneous	10% Cellulose	90% Other	None Detected
03 / 23064683-003 Ceiling Drywall & Joint Compound / Hall Ceiling, Joint Compound	White Non-Fibrous Homogeneous		100% Other	None Detected
04 / 23064683-004 Wall & Joint Compound / BDRM 1, Drywall	White Non-Fibrous Homogeneous	6% Cellulose	94% Other	None Detected
04 / 23064683-004 Wall & Joint Compound / BDRM 1, Joint Compound	Beige Non-Fibrous Homogeneous		98% Other	2% Chrysotile
04 / 23064683-004 Wall & Joint Compound / BDRM 1, Texture	White Non-Fibrous Homogeneous		100% Other	None Detected
04 / 23064683-004 Wall & Joint Compound / BDRM 1, Composite	Various Non-Fibrous Heterogeneous		100% Other	< 1% Chrysotile
05 / 23064683-005 Stipple Texture / Kitchen Ceiling	White Non-Fibrous Homogeneous		100% Other	None Detected

Amended Report: Additional Analysis Requested

Analyst: *Susan P. Childress*

Approved Signatory:

Analysis Date: 11/30/2023

Date: 11/30/2023





SanAir ID Number  
**23064683**  
FINAL REPORT  
11/30/2023 11:42:51 AM

**Name:** 3 Kings Environmental Inc.  
**Address:** PO Box 280  
Battle Ground, WA 98604  
**Phone:** 360-666-5464

**Project Number:** 223143  
**P.O. Number:** 12023-277  
**Project Name:** GI - 4801 Ph.1 & ACM-Amended Report JT  
**Collected Date:** 11/20/2023  
**Received Date:** 11/22/2023 10:10:00 AM

Analyst: Childress, Susan

### Asbestos Bulk PLM EPA 600/R-93/116

SanAir ID / Description	Stereoscopic	Components		Asbestos Fibers
	Appearance	% Fibrous	% Non-fibrous	
06 / 23064683-006 Stipple Texture / Kitchen Ceiling	White Non-Fibrous Homogeneous		100% Other	None Detected
07 / 23064683-007 Stipple Texture / Kitchen Ceiling	White Non-Fibrous Homogeneous		100% Other	None Detected
08 / 23064683-008 Drywall & Joint Compound, Light Stipple / Kitchen Wall, Drywall	White Non-Fibrous Homogeneous	4% Cellulose	96% Other	None Detected
08 / 23064683-008 Drywall & Joint Compound, Light Stipple / Kitchen Wall, Joint Compound	Beige Non-Fibrous Homogeneous		98% Other	2% Chrysotile
08 / 23064683-008 Drywall & Joint Compound, Light Stipple / Kitchen Wall, Texture	Brown Non-Fibrous Homogeneous		100% Other	None Detected
08 / 23064683-008 Drywall & Joint Compound, Light Stipple / Kitchen Wall, Composite	Various Non-Fibrous Heterogeneous		100% Other	< 1% Chrysotile
09 / 23064683-009 Drywall & Joint Compound, Light Stipple / Kitchen Wall, Drywall	White Non-Fibrous Homogeneous	4% Cellulose	96% Other	None Detected
09 / 23064683-009 Drywall & Joint Compound, Light Stipple / Kitchen Wall, Joint Compound	White Non-Fibrous Homogeneous		100% Other	None Detected
09 / 23064683-009 Drywall & Joint Compound, Light Stipple / Kitchen Wall, Texture	Brown Non-Fibrous Homogeneous		100% Other	None Detected

Amended Report: Additional Analysis Requested

Analyst: *Susan P. Childress*

Approved Signatory:

Analysis Date: 11/30/2023

Date: 11/30/2023



SanAir ID Number  
**23064683**  
FINAL REPORT  
11/30/2023 11:42:51 AM

**Name:** 3 Kings Environmental Inc.  
**Address:** PO Box 280  
Battle Ground, WA 98604  
**Phone:** 360-666-5464

**Project Number:** 223143  
**P.O. Number:** 12023-277  
**Project Name:** GI - 4801 Ph.1 & ACM-Amended Report JT  
**Collected Date:** 11/20/2023  
**Received Date:** 11/22/2023 10:10:00 AM

Analyst: Childress, Susan

### Asbestos Bulk PLM EPA 600/R-93/116

SanAir ID / Description	Stereoscopic	Components		Asbestos Fibers
	Appearance	% Fibrous	% Non-fibrous	
10 / 23064683-010 Sheet Vinyl Over Vinyl Floor Tile, Mastic / Kitchen, Sheet Vinyl	Beige Non-Fibrous Homogeneous	15% Cellulose	85% Other	None Detected
10 / 23064683-010 Sheet Vinyl Over Vinyl Floor Tile, Mastic / Kitchen, Backing/Mastic	Various Non-Fibrous Heterogeneous	15% Cellulose	60% Other	25% Chrysotile
10 / 23064683-010 Sheet Vinyl Over Vinyl Floor Tile, Mastic / Kitchen, Vinyl Tile	Beige Non-Fibrous Homogeneous		96% Other	4% Chrysotile
10 / 23064683-010 Sheet Vinyl Over Vinyl Floor Tile, Mastic / Kitchen, Mastic	Black Non-Fibrous Homogeneous		100% Other	None Detected
11 / 23064683-011 Sheet Vinyl Over Vinyl Floor Tile, Mastic / Kitchen, Sheet Vinyl	Beige Non-Fibrous Homogeneous	15% Cellulose	85% Other	None Detected
11 / 23064683-011 Sheet Vinyl Over Vinyl Floor Tile, Mastic / Kitchen, Backing/Mastic				Not Analyzed
11 / 23064683-011 Sheet Vinyl Over Vinyl Floor Tile, Mastic / Kitchen, Vinyl Tile				Not Analyzed
11 / 23064683-011 Sheet Vinyl Over Vinyl Floor Tile, Mastic / Kitchen, Mastic	Black Non-Fibrous Homogeneous		100% Other	None Detected
12 / 23064683-012 Vinyl Floor Tile, Mastic / BDRM 2, Vinyl Tile	Beige Non-Fibrous Homogeneous		96% Other	4% Chrysotile
12 / 23064683-012 Vinyl Floor Tile, Mastic / BDRM 2, Mastic	Black Non-Fibrous Homogeneous		100% Other	None Detected

Amended Report: Additional Analysis Requested

Analyst:

*Susan P. Childress*

Approved Signatory:

*[Signature]*

Analysis Date: 11/30/2023

Date: 11/30/2023



SanAir ID Number  
**23064683**  
FINAL REPORT  
11/30/2023 11:42:51 AM

**Name:** 3 Kings Environmental Inc.  
**Address:** PO Box 280  
Battle Ground, WA 98604  
**Phone:** 360-666-5464

**Project Number:** 223143  
**P.O. Number:** 12023-277  
**Project Name:** GI - 4801 Ph.1 & ACM-Amended Report JT  
**Collected Date:** 11/20/2023  
**Received Date:** 11/22/2023 10:10:00 AM

Analyst: Childress, Susan

## Asbestos Bulk PLM EPA 600/R-93/116

SanAir ID / Description	Stereoscopic	Components		Asbestos Fibers
	Appearance	% Fibrous	% Non-fibrous	
13 / 23064683-013 Vinyl Floor Tile, Mastic / Living Rm Front Entry, Vinyl Tile				Not Analyzed
13 / 23064683-013 Vinyl Floor Tile, Mastic / Living Rm Front Entry, Mastic	Black Non-Fibrous Homogeneous		100% Other	None Detected
14 / 23064683-014 Sheet Vinyl Flooring / Bathroom Floor	Beige Non-Fibrous Heterogeneous		100% Other	None Detected
15 / 23064683-015 Sheet Vinyl Flooring / Bathroom Floor	Beige Non-Fibrous Heterogeneous		100% Other	None Detected
16 / 23064683-016 Vinyl Floor Tile, Mastic / Bathroom, Vinyl Tile	Brown Non-Fibrous Homogeneous		97% Other	3% Chrysotile
16 / 23064683-016 Vinyl Floor Tile, Mastic / Bathroom, Mastic	Brown Non-Fibrous Homogeneous		100% Other	None Detected
17 / 23064683-017 Vinyl Floor Tile, Mastic / Bathroom, Vinyl Tile				Not Analyzed
17 / 23064683-017 Vinyl Floor Tile, Mastic / Bathroom, Mastic	Brown Non-Fibrous Homogeneous		100% Other	None Detected
18 / 23064683-018 Cove Base, Adhesive / Kitchen, Cove Base	Beige Non-Fibrous Homogeneous		100% Other	None Detected
18 / 23064683-018 Cove Base, Adhesive / Kitchen, Adhesive	Cream Non-Fibrous Homogeneous		100% Other	None Detected

Amended Report: Additional Analysis Requested

Analyst:

*Susan P. Childress*

Approved Signatory:

*[Signature]*

Analysis Date: 11/30/2023

Date: 11/30/2023



SanAir ID Number  
**23064683**  
FINAL REPORT  
11/30/2023 11:42:51 AM

**Name:** 3 Kings Environmental Inc.  
**Address:** PO Box 280  
Battle Ground, WA 98604  
**Phone:** 360-666-5464

**Project Number:** 223143  
**P.O. Number:** 12023-277  
**Project Name:** GI - 4801 Ph.1 & ACM-Amended Report JT  
**Collected Date:** 11/20/2023  
**Received Date:** 11/22/2023 10:10:00 AM

Analyst: Childress, Susan

### Asbestos Bulk PLM EPA 600/R-93/116

SanAir ID / Description	Stereoscopic	Components		Asbestos Fibers
	Appearance	% Fibrous	% Non-fibrous	
19 / 23064683-019 Cove Base, Adhesive / Kitchen, Cove Base	Beige Non-Fibrous Homogeneous		100% Other	None Detected
19 / 23064683-019 Cove Base, Adhesive / Kitchen, Adhesive	Cream Non-Fibrous Homogeneous		100% Other	None Detected
20 / 23064683-020 Brick & Mortar / Living Rm, Brick	Red Non-Fibrous Homogeneous		100% Other	None Detected
20 / 23064683-020 Brick & Mortar / Living Rm, Mortar	Grey Non-Fibrous Homogeneous		100% Other	None Detected
21 / 23064683-021 Brick & Mortar / Living Rm, Brick	Red Non-Fibrous Homogeneous		100% Other	None Detected
21 / 23064683-021 Brick & Mortar / Living Rm, Mortar	Grey Non-Fibrous Homogeneous		100% Other	None Detected
22 / 23064683-022 Ceilign Tiles / Bathroom	White Fibrous Homogeneous	55% Cellulose 15% Glass	30% Other	None Detected
23 / 23064683-023 Ceilign Tiles / Bathroom	White Fibrous Homogeneous	55% Cellulose 15% Glass	30% Other	None Detected
24 / 23064683-024 Mastic / Bathroom Shower	Tan Non-Fibrous Homogeneous		100% Other	None Detected
25 / 23064683-025 Mastic / Bathroom Shower	Tan Non-Fibrous Homogeneous		100% Other	None Detected

Amended Report: Additional Analysis Requested

Analyst: *Susan P. Childress*

Approved Signatory:

Analysis Date: 11/30/2023

Date: 11/30/2023



SanAir ID Number  
**23064683**  
FINAL REPORT  
11/30/2023 11:42:51 AM

**Name:** 3 Kings Environmental Inc.  
**Address:** PO Box 280  
Battle Ground, WA 98604  
**Phone:** 360-666-5464

**Project Number:** 223143  
**P.O. Number:** 12023-277  
**Project Name:** GI - 4801 Ph.1 & ACM-Amended Report JT  
**Collected Date:** 11/20/2023  
**Received Date:** 11/22/2023 10:10:00 AM

Analyst: Childress, Susan

### Asbestos Bulk PLM EPA 600/R-93/116

SanAir ID / Description	Stereoscopic	Components		Asbestos Fibers
	Appearance	% Fibrous	% Non-fibrous	
26 / 23064683-026 Bttm Layer Composite Roof	Grey Non-Fibrous Heterogeneous	5% Glass	95% Other	None Detected
27 / 23064683-027 Bttm Layer Composite Roof	Grey Non-Fibrous Heterogeneous	5% Glass	95% Other	None Detected
28 / 23064683-028 Roof Felt / Middle Layer Roof	Black Non-Fibrous Homogeneous	30% Cellulose	70% Other	None Detected
29 / 23064683-029 Roof Felt / Middle Layer Roof	Black Non-Fibrous Homogeneous	30% Cellulose	70% Other	None Detected
30 / 23064683-030 Top Layer Composite Roof	Grey Non-Fibrous Heterogeneous	5% Glass	95% Other	None Detected
31 / 23064683-031 Top Layer Composite Roof	Grey Non-Fibrous Heterogeneous	5% Glass	95% Other	None Detected

Amended Report: Additional Analysis Requested

Analyst: *Susan P. Childress*

Approved Signatory: *[Signature]*

Analysis Date: 11/30/2023

Date: 11/30/2023

## Disclaimer

This report is the sole property of the client named on the SanAir Technologies Laboratory chain-of-custody (COC). Results in the report are confidential information intended only for the use by the customer listed on the COC. Neither results nor reports will be discussed with or released to any third party without our client's written permission. The final report shall not be reproduced except in full without written approval of the laboratory to assure that parts of the report are not taken out of context. This report and any information contained within shall not be edited, altered, or modified in any way by any persons or agencies receiving, viewing, distributing, or otherwise possessing a copy of this final report. The laboratory reserves the right to perform amendments to any finalized report, of which shall supersede and make obsolete any previous editions. Such changes, modifications, additions, or deletions shall be effective immediately upon notice thereof, which may be given by means including but not limited to posting on the SanAir client portal website, electronic or conventional mail, or by any other means. The information provided in this report applies only to the samples submitted and is relevant only for the date, time, and location of sampling. The accuracy of the results is dependent upon the client's sampling procedure and information provided to the laboratory by the client on the COC. SanAir assumes no responsibility for the sampling procedure and will provide evaluation reports based solely on the sample(s) in the condition in which they arrived at the laboratory and information provided by the client on the COC, such as: project number, project name, collection dates, po number, special instructions, samples collected by, sample numbers, sample identifications, sample type, selected analysis type, flow rate, total volume or area, and start stop times that may affect the validity of the results in this report. Samples were received in good condition unless otherwise noted on the report. SanAir assumes no responsibility or liability for the manner in which the results are used or interpreted. This report does not constitute nor shall not be used by the client to claim product, process, system, or person certification, approval, or endorsement by NVLAP, NIST, NELAC, AIHA LAP, LLC or any other U.S. governmental agencies and may not be accredited by every local, state, and federal regulatory agencies. Samples are held for a period of 60 days. Fibers smaller than 5 microns cannot be seen with this method due to scope limitations. For NY state samples, method EPA 600/M4-82-020 is performed.

### NYELAP Disclaimer:

Polarized- light microscopy is not consistently reliable in detecting asbestos in floor covering and similar non-friable organically bound materials. Quantitative transmission electron microscopy is currently the only method that can be used to determine if this material can be considered or treated as non-asbestos containing.

### Asbestos Accreditations

National Voluntary Laboratory Accreditation Program (NVLAP) Lab Code 200870-0  
City of Philadelphia Department of Public Health Air Management Services, Certification#ALL-460  
Commonwealth of Pennsylvania Department of Environmental Protection Number 68-05397  
California State Environmental Laboratory Accreditation Program Certificate Number 2915  
Colorado Department of Public Health and Environment Registration Number AL-23143  
Connecticut Department of Public Health Environmental Laboratory Registration Number PH-0105  
Massachusetts Department of Labor Standards Asbestos Analytical Services License Number: AA000222  
State of Maine Department of Environmental Protection License Number: LB-0075, LA-0084  
New York State Department of Health Laboratory ID: 11983  
State of Rhode Island Department of Health Certification No.: PCM00126, PLM00126, TEM00126  
Texas Department of State Health Services License Number: 300440  
Commonwealth of Virginia Department of Professional and Occupational Regulation Number: 3333000323  
State of Washington Department of Ecology Laboratory ID: C989  
State of West Virginia Bureau for Public Health Analytical Laboratory Number: LT000616  
Vermont Department of Health License Number: Asb-Co-An-000006  
Louisiana Department of Environmental Quality AI Number 212253, Certificate #05088





10501 Trade Ct., Suite 100  
N. Chesterfield, VA 23236  
804.897.1177 / 888.895.1177  
Fax 804.897.0070  
[sanair.com](http://sanair.com)

**Asbestos**  
**Chain of Custody**  
Form 140, Rev 7, 10/20/2022

SanAir ID Number

13064683

Company: <b>3 Kings Environmental Inc.</b>	Project #: <b>223143</b>	Collected by: <b>Emily Weiss</b>
Address: <b>PO Box 280</b>	Project Name: <b>GI - 4801 Ph.1 &amp; ACM</b>	Phone #: <b>360-750-4143</b>
City, St., Zip: <b>Battle Ground, WA 98604</b>	Date Collected: <b>11/20/2023</b>	Fax #: <b>360-750-4462</b>
State of Collection: <b>WA</b> Account#: <b>2344</b>	P.O. Number: <b>12023-277</b>	Email: <b>e.weiss@3kingsinc.com</b>

Bulk		Air		Soil	
ABB	PLM EPA 600/R-93/116 <input checked="" type="checkbox"/>	ABA	PCM NIOSH 7400 <input type="checkbox"/>	ABSE	PLM EPA 600/R-93/116 (Qual.) <input type="checkbox"/>
	Positive Stop <input checked="" type="checkbox"/>	ABA-2	OSHA w/ TWA* <input type="checkbox"/>	<b>Vermiculite</b>	
ABEPA	PLM EPA 400 Point Count <input type="checkbox"/>	ABTEM	TEM AHERA <input type="checkbox"/>	ABB	PLM EPA 600/R-93/116 <input type="checkbox"/>
ABB1K	PLM EPA 1000 Point Count <input type="checkbox"/>	ABATN	TEM NIOSH 7402 <input type="checkbox"/>	ABEPA3	PLM EPA 400 Point Count <input type="checkbox"/>
ABBEN	PLM EPA NOB** <input type="checkbox"/>	ABT2	TEM Level II <input type="checkbox"/>	ABCM	Cincinnati Method <input type="checkbox"/>
ABBCH	TEM Chatfield** <input type="checkbox"/>	Other:	<input type="checkbox"/>	<b>Dust</b>	
ABBTM	TEM EPA NOB** <input type="checkbox"/>	<b>New York ELAP</b>		ABWA	TEM Wipe ASTM D-6480 <input type="checkbox"/>
ABQ	PLM Qualitative <input type="checkbox"/>	ABEPA2	NY ELAP 198.1 <input type="checkbox"/>	ABDMV	TEM Microvac ASTM D-5755 <input type="checkbox"/>
		ABENY	NY ELAP 198.6 PLM NOB <input type="checkbox"/>		
		ABBNY	NY ELAP 198.4 TEM NOB <input type="checkbox"/>		
		Positive Stop <input type="checkbox"/>		Matrix	Other <input type="checkbox"/>

\*\* Available on 24-hr. to 5-day TAT

Water	
ABHE	EPA 100.2 <input type="checkbox"/>

Turn Around Times	3 HR (4 HR TEM) <input type="checkbox"/>	6 HR (8HR TEM) <input type="checkbox"/>	12 HR <input type="checkbox"/>	1 Day <input checked="" type="checkbox"/>
	<input type="checkbox"/> 2 Days	<input type="checkbox"/> 3 Days	<input type="checkbox"/> 4 Days	<input type="checkbox"/> 5 Days

Special Instructions	
----------------------	--

Sample #	Sample Identification/Location	Volume or Area	Sample Date	Flow Rate*	Start - Stop Time*
01	Ceiling Texture / Living Room				
02	Ceiling Drywall & Joint Compound / adj. Sliding				
03	Ceiling Drywall & Joint Compound / Hall Ceiling				
04	Wall drywall & Joint Compound / BDRM 1				
05	Stipple Texture / Kitchen Ceiling				
06	Stipple Texture / Kitchen Ceiling				
07	Stipple Texture / Kitchen Ceiling				
08	Drywall & Joint Compund, Light Stipple / Kitchen Wall				
09	Drywall & Joint Compund, Light Stipple / Kitchen Wal				
10	Beige Sheet Vinyl over Vinyl Floor Tile, Blk Mastic / Kitchen				
11	Beige Sheet Vinyl over Vinyl Floor Tile, Blk Mastic / Kitchen				
12	Vinyl Floor Tile, Mastic / BDRM 2				

Relinquished by	Date	Time	Received by	Date	Time
Emily Weiss	11/20/23	12:30pm	<i>LAC</i>	11/22/23	10:10am

If no technician is provided, then the primary contact for your account will be selected. Unless scheduled, the turnaround time for all samples received after 3 pm EST will be logged in the next business day. Weekend or holiday work must be scheduled ahead of time and is charged at 150% of the 3hr TAT or a minimum charge of \$150. A courier charge will be applied for same day and one-day turnaround times for offsite work. SanAir covers Ground and Next Day Air shipping. Shipments billed to SanAir with a faster shipping rate will result in additional charges.

[illegible]

<b>Special Instructions</b>	
-----------------------------	--

Relinquished by	Date	Time	Received by	Date	Time
Emily Weiss	11/20/23	12:30pm	<i>[Signature]</i>	11/20/23	10:10am

If no technician is provided, then the primary contact for your account will be selected. Unless scheduled, the turnaround time for all samples received after 3 pm EST will be logged in the next business day. Weekend or holiday work must be scheduled ahead of time and is charged at 150% of the 3hr TAT or a minimum charge of \$150. A courier charge will be applied for same day and one-day turnaround times for offsite work. SanAir covers Ground and Next Day Air shipping. Shipments billed to SanAir with a faster shipping rate will result in additional charges. Page of 2 2

# CERTIFICATION

# AHERA

## BUILDING INSPECTOR INITIAL CERTIFICATE

This is to certify that


*Emily Weiss*

has attended and satisfactorily completed all requirements to maintain accreditation as  
an AHERA Building Inspector in accordance with the Toxic Substance Control  
Act Title (Section 206) and 40 CFR 763.

**Accreditation No. BI-NES-07-26-23-02**

**Course Date: July 24<sup>th</sup> - July 26<sup>th</sup>, 2023**

**Valid through: July 24<sup>th</sup> - July 26<sup>th</sup>, 2024**



NOW Environmental Services, Inc.  
34004 – 9<sup>th</sup> Avenue South, Suite # 12  
Federal Way, Washington 98003  
(253) 927-5233