



Notice of Intent to Remove Asbestos

Case #: 24-150

Amendment: 0

11815 NE 99th Street, Suite 1294
Vancouver, WA 98662
Voice: 360-574-3058
Fax: 360-576-0925
Web: <https://www.swcleanair.gov>
Email: Tina@swcleanair.gov

Date Received: 3/12/2024

Date Paid: 3/12/2024

SWCAA Fee: \$738.00

Receipt #: 152655079

This notification MUST be present at all times at the asbestos project sit

***** EMERGENCY NOTICE *****

Quantity to be removed: 372 Square Feet 0 Linear Feet Workshift days: W

Project starting date: 3/13/2024 Project Completion date: 3/13/2024 Workshift hours: 8:00am-4:30pm

Site Name: Fields Residence Site address: 1208 C St

Location of Asbestos: Kitchen Laundry foyer, bathroom City/State/Zip: Washougal WA 98671

Demolition of Structure (Notification of Demolition required) County: CLARK COUNTY

Asbestos survey conducted? No survey reason:

AHERA Inspector: Occupant Owner Certification #:

Material to be Removed:

Fireproofing Popcorn Ceiling CAB Sheet Vinyl Boiler Insulation Duct Tape

Duct Paper Mag Pipe Insulation Air Cell CA Pipe VAT

Other

Control Methods:

N.P Enclosure Glove Bag Mini Enclosure Wrap and Cut Water HEPA Vac

Other Regulate Area

Asbestos Contractor: Minority Abatement Contractors, Inc. Phone: 360-750-1900

Mailing Address: 3200 NE 65th St, Vancouver, WA, 98663 Email: vwhitebird@minorityac.com

Certification ##: ABCN00001346

Supervisor: Jesus Ortiz Phone: 360-605-7958

Property Owner: Justin Fields Phone: 360-573-4421

Mailing Address: 1208 C St, Washougal WA 98671

Asbestos Disposal Site: Wasco County Landfill: 2550 Steele Rd, The Dalles, OR, 97058-

I DO HEREBY CERTIFY THAT THE INFORMATION CONTAINED IN THIS NOTIFICATION IS, TO THE BEST OF MY KNOWLEDGE, ACCURATE AND COMPLETE.

Submitter Name: Guillermo Plaza **Representing:** Minority Abatement Contract

Submitter Title: Project Manager **Date Submitted:** 3/12/2024

Reviewed by SWCAA: Mihai Voivod Approved



11815 NE 99th Street, Suite 1294
Vancouver, WA 98662
Voice: 360-574-3058
Fax: 360-576-0925
Web: <https://www.swcleanair.gov>
Email: Tina@swcleanair.gov

Notice of Intent to Remove Asbestos

Case #: 24-150

Amendment: 0

Date Received: 3/12/2024

Date Paid: 3/12/2024

SWCAA Fee: \$738.00

Receipt #: 152655079

This notification MUST be present at all times at the asbestos project sit



Minority Abatement Contractors, INC.

3200 NE 65th St, Vancouver, WA 98663

phone: 360.750.1900

fax: 360.750.1901

March 12, 2024

BY E-MAIL

Southwest Clean Air Agency
Vancouver, Washington
(360) 576-0925

Re: 1208 C St Washougal, WA 98671

Subject: Request of Emergency Waiver

To: Whom it may concern

We respectfully request a waiver from the 10-day waiting period, to receive an asbestos abatement permit. We offer the following explanation for this request.

Minority Abatement Contractors, Inc was contacted by Theresa Hall with Service master. Due to water damage, they performed a limited asbestos testing, and it turns out that the floors tested positive for asbestos. For the restoration company to remediate the damage, removal of asbestos containing flooring needs to be abated. (MAC) would like to perform this work on Wednesday 3/13/2024.

Again, thank you for your assistance. Please feel free to contact me with any questions or comments you might have.

Very truly yours,

MINORITY ABATEMENT CONTRACTORS, INC.

Guillermo Plaza
Project manager
503-421-1573 Cell
360-750-1900 office



Batch # 2022 *

22-1202501

Analysis Date *

02/28/2024

Project #

L24-0151

Analyst *

Crossland Kapaun

Name / Company *

ServiceMaster by JTS

Project Name

Fields

PO #

Project Location *

1208 C St., Washougal, WA
98671

Turnaround Time *

Rush

Asbestos Analysis of Bulk Material by Polarized Light Microscopy

Sample*	Layer*	Description*	Non Asbestos*	Asbestos Type*	Asbestos %*
1	1	Vinyl (Red) - Kitchen Floor	Cellulose	Chrysotile	25%
1	2	Mastic (Yellow) - Kitchen Floor	Cellulose	Chrysotile	2%
2	1	Drywall (White) - Utility Wall	Cellulose	None Present	N/D
2	2	Texture (White) - Utility Wall	Cellulose	None Present	N/D

To Be Filled by the Technician

Technician *

Atlas Laboratories maintains liability to cost of analysis. This report relates only to the samples reported and may not be reproduced, except in full without written permission by Atlas. Atlas bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client.



Batch # 2022 *

22-1212301

Analysis Date *

03/04/2024

Project #

L24-0151

Analyst *

Dillon Lafever

Name / Company *

ServiceMaster by JTS

Project Name

Feilds

PO #

Project Location *

1208 C St., Washougal, WA
98671

Turnaround Time *

Rush

Asbestos Analysis of Bulk Material by Polarized Light Microscopy

Sample*	Layer*	Description*	Non Asbestos*	Asbestos Type*	Asbestos %*
1	1	Vinyl (Grey) - Foyer Floor	Cellulose	Chrysotile	25%
1	2	Mastic (Yellow) - Foyer Floor	Cellulose	Chrysotile	2%
1	3	Leveling Compound (Tan) - Foyer Floor	Cellulose	Chrysotile	2%

To Be Filled by the Technician

Technician *

Atlas Laboratories maintains liability to cost of analysis. This report relates only to the samples reported and may not be reproduced, except in full without written permission by Atlas. Atlas bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. This report must not be used by the client to claim product certification, approval or endorsement by NVLAP, NIST,