



11815 NE 99th Street, Suite 1294
Vancouver, WA 98662
Voice: 360-574-3058
Fax: 360-576-0925
Web: <https://www.swcleanair.gov>
Email: Tina@swcleanair.gov

Notice of Intent to Remove Asbestos

Case #: 24-238

Amendment: 0

Date Received: 4/15/2024

Date Paid: 4/15/2024

SWCAA Fee: \$369.00

Receipt #: 154581983

This notification MUST be present at all times at the asbestos project sit

Quantity to be removed: 560 Square Feet 0 Linear Feet

Workshift days: Th

Project starting date: 4/25/2024 Project Completion date: 4/25/2024

Workshift hours: 8:00AM - 4:30PM

Site Name: Greg Bean

Site address: 2107 Cascade Way

Location of Asbestos: Living room

City/State/Zip: Longview

WA

98632

☐ Demolition of Structure (Notification of Demolition required)

County: COWLITZ COUNTY

☐ Asbestos survey conducted?

No survey reason:

AHERA Inspector: Kyler Spears

Certification #: 187341

Material to be Removed:

- | | | | | | |
|--|--|------------------------------|--------------------------------------|--|------------------------------------|
| ☐ Fireproofing | ☐ Popcorn Ceiling | ☐ CAB | ☐ Sheet Vinyl | ☐ Boiler Insulation | ☐ Duct Tape |
| ☐ Duct Paper | ☐ Mag Pipe Insulation | | ☐ Air Cell | ☐ CA Pipe | ☐ VAT |
| ☒ Other Mastic | | | | | |

Control Methods:

- | | | | | | |
|--|------------------------------------|---|---------------------------------------|---|-----------------------------------|
| ☒ N.P Enclosure | ☐ Glove Bag | ☐ Mini Enclosure | ☐ Wrap and Cut | ☒ Water | ☐ HEPA Vac |
| ☒ Other Manual Methods | | | | | |

Asbestos Contractor: Keystone Contracting, Inc.

Phone: 360-887-0868

Mailing Address: 417 NW 209th St, Ridgefield, WA, 98642

Email: keystone417@tds.net

Certification ##: ABCN00001024

Supervisor: Martin Ortiz

Phone: 360-353-6423

Property Owner: Greg Bean

Phone: 360-957-0013

Mailing Address: 2107 Cascade Way, Longview WA 98632

Asbestos Disposal Site: Wasco County Landfill: 2550 Steele Rd, The Dalles, OR, 97058-

**I DO HEREBY CERTIFY THAT THE INFORMATION CONTAINED IN THIS NOTIFICATION IS,
TO THE BEST OF MY KNOWLEDGE, ACCURATE AND COMPLETE.**

Submitter Name: Kamala Lopez

Representing: Keystone Contracting, Inc

Submitter Title: Office Manager

Date Submitted: 4/15/2024

Reviewed by SWCAA: Mihai Voivod

☒ Approved



11815 NE 99th Street, Suite 1294
Vancouver, WA 98662
Voice: 360-574-3058
Fax: 360-576-0925
Web: <https://www.swcleanair.gov>
Email: Tina@swcleanair.gov

Notice of Intent to Remove Asbestos

Case #: 24-238

Amendment: 0

Date Received: 4/15/2024

Date Paid: 4/15/2024

SWCAA Fee: \$369.00

Receipt #: 154581983

This notification MUST be present at all times at the asbestos project sit

❖ CERTIFIED ENVIRONMENTAL CONSULTING, LLC ❖

BULK SAMPLE ANALYSIS REPORT

CLIENT: SERVPRO OF LONGVIEW/KELSO
MR. RYAN GRADY
1425 ALABAMA STREET SUITE #G
LONGVIEW, WASHINGTON 98632

SOURCE: GREG BEAN, 2107 CASCADE WAY,
LONGVIEW, WASHINGTON
SAMPLED BY: CLIENT
LAB # JJ-500
ANALYZED BY: KYLER SPEARS

DATE SAMPLED: 04-05-24
DATE RECEIVED: 04-08-24
DATE COMPLETED: 04-08-24

ANALYTICAL METHOD: EPA 600/R-93/116, 40 CFR Part 763, Subpart E, Appendix E, Section #1, PLM/Dispersion Staining

SAMPLE ID #	SAMPLE DESCRIPTION	SAMPLE LOCATION	ASBESTOS CONTENT % TYPE	OTHER MATERIAL
1	BEIGE ROCK PATTERN SHEET VINYL	HALLWAY	20% CHRYSOTILE	3% CELLULOSE, VINYL, CALCITE, ADHESIVE
2	BROWN MASTIC	LIVING ROOM	3% ANTHOPHYLLITE	CLAY, ADHESIVE, BINDER
3	CREAM CERAMIC TILE AND MORTAR	KITCHEN	NONE DETECTED	AGGREGATE, CEMENT, CERAMIC
4	CREAM CERAMIC TILE AND MORTAR	KITCHEN	NONE DETECTED	AGGREGATE, CEMENT, CERAMIC

ANALYST: 

REVIEWED BY: 

DEVIATION FROM METHOD: NONE.

PERCENTAGES ARE ESTIMATES.

TEST RESULTS PERTAIN ONLY TO ITEMS TESTED.

* DETECTION LIMIT IS LESS THAN 1% ASBESTOS.

NON-ASBESTOS MATERIALS ARE NOT NECESSARILY LISTED.

❖ CERTIFIED ENVIRONMENTAL CONSULTING, LLC ❖

BULK SAMPLE ANALYSIS REPORT

CLIENT: SERVPRO OF LONGVIEW/KELSO
MR. RYAN GRADY
1425 ALABAMA STREET SUITE #G
LONGVIEW, WASHINGTON 98632

SOURCE: GREG BEAN, 2107 CASCADE WAY,
LONGVIEW, WASHINGTON
SAMPLED BY: CLIENT
LAB # JJ-500
ANALYZED BY: KYLER SPEARS

DATE SAMPLED: 04-05-24
DATE RECEIVED: 04-08-24
DATE COMPLETED: 04-08-24

ANALYTICAL METHOD: EPA 600/R-93/116, 40 CFR Part 763, Subpart E, Appendix E, Section #1, PLM/Dispersion Staining

SAMPLE ID #	SAMPLE DESCRIPTION	SAMPLE LOCATION	ASBESTOS CONTENT % TYPE	OTHER MATERIAL
5	CREAM CERAMIC TILE AND MORTAR	KITCHEN	NONE DETECTED	AGGREGATE, CEMENT, CERAMIC
6	WHITE GYPSUM WALLBOARD WITH JOINT COMPOUND	LIVING ROOM	NONE DETECTED	15% FIBERGLASS, 10% CELLULOSE, CALCIUM SULFATE, CALCIUM CARBONATE, BINDER
7	WHITE GYPSUM WALLBOARD WITH JOINT COMPOUND	LIVING ROOM	NONE DETECTED	15% FIBERGLASS, 10% CELLULOSE, CALCIUM SULFATE, CALCIUM CARBONATE, BINDER
8	WHITE GYPSUM WALLBOARD WITH JOINT COMPOUND	LIVING ROOM	NONE DETECTED	15% FIBERGLASS, 10% CELLULOSE, CALCIUM SULFATE, CALCIUM CARBONATE, BINDER

ANALYST:

DEVIATION FROM METHOD: NONE.
PERCENTAGES ARE ESTIMATES.
TEST RESULTS PERTAIN ONLY TO ITEMS TESTED.
* DETECTION LIMIT IS LESS THAN 1% ASBESTOS.
NON-ASBESTOS MATERIALS ARE NOT NECESSARILY LISTED.

REVIEWED BY:

◆ CERTIFIED ENVIRONMENTAL CONSULTING, LLC. ◆

615 SE CHKALOV DRIVE SUITE 12, VANCOUVER, WASHINGTON 98683-5280
(503) 221-7904 PHONE (360) 254-9385 FAX-(360) 891-9633

LAB# U500 CLIENT: Servpro of Longview / Kelso CONTACT: Ryan Grady SAMPLE DATE: 4-5-24
BILLING ADDRESS: 1425 Alabama Street Seattle CITY/STATE: Longview WA ZIP CODE: 98632
PHONE: 360-703-3884 EMAIL: Servpro.berry@gmail.com FAX: _____ ANALYSIS REQUESTED: _____
SAMPLED BY: Linda Hobson PROJECT NAME AND ADDRESS: Greg Bean 2107 Cascade Way CITY/STATE: Longview, WA
NORMAL [] (END OF 3RD BUSINESS DAY) RUSH [X] (END OF NEXT BUSINESS DAY) 98632

SAMPLE #	DESCRIPTION OF MATERIAL (I.E. SHEET VINYL, FLOOR TILE, CEILING TEXTURE WITH COLOR)	SAMPLE LOCATION (WHICH ROOM OR AREA THE SAMPLE WAS COLLECTED)
1	Beigh Rock pattern Sheet Vinyl	Hallway
2	Brown mastic	Living Room
3	cream Tile & Mortar	Kitchen
4	cream Tile & Mortar	Kitchen
5	cream Tile & Mortar	Kitchen
6	white Dry wall / white compound	Living Room
7	white Dry wall / white compound	Living Room
8	white Dry wall / white compound	Living Room

SENT TO: CEC RELINQUISHED BY (PRINT): Linda Hobson RELINQUISHED BY (SIGNATURE): Linda Hobson

RECEIVED BY: EV Dropbox DATE RECEIVED: 4-8-24