



11815 NE 99th Street, Suite 1294
Vancouver, WA 98662
Voice: 360-574-3058
Fax: 360-576-0925
Web: <https://www.swcleanair.gov>
Email: Tina@swcleanair.gov

Notice of Intent to Remove Asbestos

Case #: 24-855

Amendment: 0

Date Received: 12/18/2024

Date Paid: 12/18/2024

SWCAA Fee: \$369.00

Receipt #: 167931135

This notification MUST be present at all times at the asbestos project sit

Quantity to be removed: 529 Square Feet 0 Linear Feet

Workshift days: M

Project starting date: 12/30/2024 Project Completion date: 12/30/2024

Workshift hours: 8:00am04:30pm

Site Name: Chechelnitskiy Residence

Site address: 1700 NE 199th St

Location of Asbestos: Basement bedrooms

City/State/Zip: Ridgefield

WA 98642

☐ Demolition of Structure (Notification of Demolition required)

County: CLARK COUNTY

☒ Asbestos survey conducted?

No survey reason:

AHERA Inspector: Occupant Owner

Certification #:

Material to be Removed:

- ☐ Fireproofing ☐ Popcorn Ceiling ☐ CAB ☐ Sheet Vinyl ☐ Boiler Insulation ☐ Duct Tape
☐ Duct Paper ☐ Mag Pipe Insulation ☐ Air Cell ☐ CA Pipe ☒ VAT
☒ Other mastic

Control Methods:

- ☒ N.P Enclosure ☐ Glove Bag ☐ Mini Enclosure ☐ Wrap and Cut ☒ Water ☒ HEPA Vac
☒ Other Regulate area

Asbestos Contractor: Minority Abatement Contractors, Inc.

Phone: 360-750-1900

Mailing Address: 3200 NE 65th St, Vancouver, WA, 98663

Email: vwhitebird@minorityac.com

Certification ##: ABCN00001346

Supervisor: Martin Ortiz

Phone: 503-991-1389

Property Owner: George Chechelnitskiy

Phone: 503-318-5700

Mailing Address: 1700 NE 199th St, Ridgefield WA 98642

Asbestos Disposal Site: Wasco County Landfill: 2550 Steele Rd, The Dalles, OR, 97058-

**I DO HEREBY CERTIFY THAT THE INFORMATION CONTAINED IN THIS NOTIFICATION IS,
TO THE BEST OF MY KNOWLEDGE, ACCURATE AND COMPLETE.**

Submitter Name: Guillermo Plaza

Representing: Minority Abatement Contract

Submitter Title: Project Manager

Date Submitted: 12/18/2024

Reviewed by SWCAA: Mihai Voivod

☒ Approved



11815 NE 99th Street, Suite 1294
Vancouver, WA 98662
Voice: 360-574-3058
Fax: 360-576-0925
Web: <https://www.swcleanair.gov>
Email: Tina@swcleanair.gov

Notice of Intent to Remove Asbestos

Case #: 24-855

Amendment: 0

Date Received: 12/18/2024

Date Paid: 12/18/2024

SWCAA Fee: \$369.00

Receipt #: 167931135

This notification MUST be present at all times at the asbestos project sit



Batch # 2022 *

22-1705901

Analysis Date *

12/10/2024

Project #

Name / Company *

AmeriDream Construction

Project Name

George

PO #

Analyst *

Crossland Kapaun

Project Location *

1700 NE 199th St.,
Ridgefield, WA 98642

Turnaround Time *

Rush

Asbestos Analysis of Bulk Material by Polarized Light Microscopy

Sample*	Layer*	Description*	Non Asbestos*	Asbestos Type*	Asbestos %*
1	1	Drywall (White) - Laundry	Cellulose	None Present	N/D
1	2	Texture (White) - Laundry	Cellulose	None Present	N/D
2	1	Texture Debris (White) - Master Bed Flooring	Cellulose	Chrysotile	2%
2	2	VCT (Brown) - Master Bed Flooring	Cellulose	Chrysotile	5%
2	3	Mastic (Black) - Master Bed Flooring	Cellulose	Chrysotile	2%

To Be Filled by the Technician
Technician *

CK