



11815 NE 99th Street, Suite 1294  
Vancouver, WA 98662  
Voice: 360-574-3058  
Fax: 360-576-0925  
Web: <https://www.swcleanair.gov>  
Email: [Tina@swcleanair.gov](mailto:Tina@swcleanair.gov)

## Notice of Intent to Remove Asbestos

Case #: 24-874

Amendment: 0

Date Received: 12/24/2024

Date Paid: 12/24/2024

SWCAA Fee: \$147.00

Receipt #: 168212212

**This notification MUST be present at all times at the asbestos project sit**

Quantity to be removed: 141 Square Feet 0 Linear Feet

Workshift days: M

Project starting date: 1/6/2025

Project Completion date: 1/6/2025

Workshift hours: 8:00AM - 4:30PM

Site Name: Family Residence

Site address: 620 25th Ave

Location of Asbestos: Utility room, Kitchen

City/State/Zip: Longview

WA

98632

☐ Demolition of Structure (Notification of Demolition required)

County: COWLITZ COUNTY

☐ Asbestos survey conducted?

No survey reason:

AHERA Inspector: Unknown. Bulk Sampling Provided b

Certification #: Non Listed.

### Material to be Removed:

☐ Fireproofing

☐ Popcorn Ceiling

☐ CAB

☒ Sheet Vinyl

☐ Boiler Insulation

☐ Duct Tape

☐ Duct Paper

☐ Mag Pipe Insulation

☐ Air Cell

☐ CA Pipe

☐ VAT

☒ Other Underlayment

### Control Methods:

☒ N.P Enclosure

☐ Glove Bag

☐ Mini Enclosure

☐ Wrap and Cut

☒ Water

☐ HEPA Vac

☒ Other Manual Methods

Asbestos Contractor: Keystone Contracting, Inc.

Phone: 360-887-0868

Mailing Address: 417 NW 209th St, Ridgefield, WA, 98642

Email: [keystone417@tds.net](mailto:keystone417@tds.net)

Certification ##: ABCN00001024

Supervisor: Juan Villegas

Phone: 503-855-8353

Property Owner: Cerisse Strehlau

Phone: 360-703-3884

Mailing Address: 3465 Indian Creek Dr., Longview WA 98632

Asbestos Disposal Site: Wasco County Landfill: 2550 Steele Rd, The Dalles, OR, 97058-

**I DO HEREBY CERTIFY THAT THE INFORMATION CONTAINED IN THIS NOTIFICATION IS,  
TO THE BEST OF MY KNOWLEDGE, ACCURATE AND COMPLETE.**

Submitter Name: Kamala Lopez

Representing: Keystone Contracting, Inc

Submitter Title: Office Manager

Date Submitted: 12/24/2024

Reviewed by SWCAA: Mihai Voivod

☒ Approved



11815 NE 99th Street, Suite 1294  
Vancouver, WA 98662  
Voice: 360-574-3058  
Fax: 360-576-0925  
Web: <https://www.swcleanair.gov>  
Email: [Tina@swcleanair.gov](mailto:Tina@swcleanair.gov)

## Notice of Intent to Remove Asbestos

Case #: 24-874

Amendment: 0

Date Received: 12/24/2024

Date Paid: 12/24/2024

SWCAA Fee: \$147.00

Receipt #: 168212212

**This notification MUST be present at all times at the asbestos project sit**

# ❖ CERTIFIED ENVIRONMENTAL CONSULTING, LLC ❖

## BULK SAMPLE ANALYSIS REPORT

**CLIENT:** SERVPRO OF LONGVIEW/KELSO  
MR. RYAN GRADY  
1425 ALABAMA STREET SUITE #G  
LONGVIEW, WASHINGTON 98632

**SOURCE:** CERISSE STREHLAU, 620 25<sup>TH</sup> AVENUE,  
LONGVIEW, WASHINGTON  
**SAMPLED BY:** CLIENT  
**LAB #** JJ-1406  
**ANALYZED BY:** ERIC S. VIKEN

**DATE SAMPLED:** 12-13-24  
**DATE RECEIVED:** 12-16-24  
**DATE COMPLETED:** 12-16-24

ANALYTICAL METHOD: EPA 600/R-93/116, 40 CFR Part 763, Subpart E, Appendix E, Section #1, PLM/Dispersion Staining

SAMPLE ID #	SAMPLE DESCRIPTION	SAMPLE LOCATION	ASBESTOS CONTENT % TYPE	OTHER MATERIAL
1	WHITE GYPSUM WALLBOARD	KITCHEN	NONE DETECTED	15% CELLULOSE, 5% FIBERGLASS, CALCIUM SULFATE, BINDER
2	WHITE GYPSUM WALLBOARD	KITCHEN	NONE DETECTED	15% CELLULOSE, 5% FIBERGLASS, CALCIUM SULFATE, BINDER
3	WHITE GYPSUM WALLBOARD	KITCHEN	NONE DETECTED	15% CELLULOSE, 5% FIBERGLASS, CALCIUM SULFATE, BINDER
4	WHITE PLASTER	KITCHEN	NONE DETECTED	3% CELLULOSE, CALCIUM CARBONATE, AGGREGATE, CEMENT
5	WHITE PLASTER	KITCHEN	NONE DETECTED	3% CELLULOSE, CALCIUM CARBONATE, AGGREGATE, CEMENT

**ANALYST:** 

**REVIEWED BY:** 

DEVIATION FROM METHOD: NONE.

PERCENTAGES ARE ESTIMATES.

TEST RESULTS PERTAIN ONLY TO ITEMS TESTED.

\* DETECTION LIMIT IS LESS THAN 1% ASBESTOS.

NON-ASBESTOS MATERIALS ARE NOT NECESSARILY LISTED.



## ❖ CERTIFIED ENVIRONMENTAL CONSULTING, LLC ❖

## BULK SAMPLE ANALYSIS REPORT

**CLIENT:** SERVPRO OF LONGVIEW/KELSO  
 MR. RYAN GRADY  
 1425 ALABAMA STREET SUITE #G  
 LONGVIEW, WASHINGTON 98632

**SOURCE:** CERISSE STREHLAU, 620 25<sup>TH</sup> AVENUE,  
 LONGVIEW, WASHINGTON  
**SAMPLED BY:** CLIENT  
**LAB #** JJ-1406  
**ANALYZED BY:** ERIC S. VIKEN

**DATE SAMPLED:** 12-13-24  
**DATE RECEIVED:** 12-16-24  
**DATE COMPLETED:** 12-16-24

ANALYTICAL METHOD: EPA 600/R-93/116, 40 CFR Part 763, Subpart E, Appendix E, Section #1, PLM/Dispersion Staining

SAMPLE ID #	SAMPLE DESCRIPTION	SAMPLE LOCATION	ASBESTOS CONTENT % TYPE	OTHER MATERIAL
6	WHITE PLASTER	KITCHEN	NONE DETECTED	3% CELLULOSE, CALCIUM CARBONATE, AGGREGATE, CEMENT
7A	WHITE MASTIC	KITCHEN	NONE DETECTED	CLAY, ADHESIVE
7B	BROWN MASTIC	KITCHEN	NONE DETECTED	3% CELLULOSE, CLAY, ADHESIVE
8A	BROWN/GREEN SHEET VINYL	TOP LAYER KITCHEN	NONE DETECTED	20% CELLULOSE, 3% FIBERGLASS, VINYL, CALCITE, ADHESIVE
8B	WHITE WITH GRAY LINES SHEET VINYL	SECOND LAYER KITCHEN	15% CHRYSOTILE	5% CELLULOSE, VINYL, CALCITE, ADHESIVE
8C	WHITE/BROWN SHEET VINYL	BOTTOM LAYER KITCHEN	NONE DETECTED	20% CELLULOSE, 3% FIBERGLASS, VINYL, CALCITE, ADHESIVE

**ANALYST:** 

DEVIATION FROM METHOD: NONE.

PERCENTAGES ARE ESTIMATES.

TEST RESULTS PERTAIN ONLY TO ITEMS TESTED.

\* DETECTION LIMIT IS LESS THAN 1% ASBESTOS.

NON-ASBESTOS MATERIALS ARE NOT NECESSARILY LISTED.

**REVIEWED BY:** 

# ◆ CERTIFIED ENVIRONMENTAL CONSULTING, LLC. ◆

615 SE CHKALOV DRIVE SUITE 12, VANCOUVER, WASHINGTON 98683-5280  
(503) 221-7904 PHONE (360) 254-9385 FAX (360) 891-9633

LAB# 11/406 CLIENT: Servpro of Longview / Kelso CONTACT: Ryan Grady SAMPLE DATE: 12-18-24  
BILLING ADDRESS: 1425 Alabama Street Seaside CITY/STATE: Longview WA ZIP CODE: 98632  
PHONE: 360-703-3884 EMAIL: Servpro.berry@gmail.com FAX: \_\_\_\_\_ ANALYSIS REQUESTED: \_\_\_\_\_  
SAMPLED BY: Linda Hobson PROJECT NAME AND ADDRESS: Carisse Strehlan 1420 25th AVE CITY/STATE: Longview, WA  
NORMAL [ ] (END OF 3<sup>RD</sup> BUSINESS DAY) RUSH [X] (END OF NEXT BUSINESS DAY) 98632

SAMPLE #	DESCRIPTION OF MATERIAL (I.E. SHEET VINYL, FLOOR TILE, CEILING TEXTURE WITH COLOR)	SAMPLE LOCATION (WHICH ROOM OR AREA THE SAMPLE WAS COLLECTED)
1	white Drywall	Kitchen
2	white Drywall	Kitchen
3	white Drywall	Kitchen
4	white plaster	Kitchen
5	white plaster	Kitchen
6	white plaster	Kitchen
7	white & Brown mastic	Kitchen
8A B C	Top - Brown/Green sheet vinyl M - white & grey line sheet vinyl B - white & Brown sheet vinyl	Kitchen

SENT TO: CPC RELINQUISHED BY (PRINT): Linda Hobson RELINQUISHED BY (SIGNATURE): Linda Hobson  
RECEIVED BY: [Signature] DATE RECEIVED: 12-16-24