



Notice of Intent to Remove Asbestos

Case #: 25-019

Amendment: 0

11815 NE 99th Street, Suite 1294
Vancouver, WA 98662
Voice: 360-574-3058
Fax: 360-576-0925
Web: <https://www.swcleanair.gov>
Email: Tina@swcleanair.gov

Date Received: 1/7/2025

Date Paid: 1/7/2025

SWCAA Fee: \$768.00

Receipt #: 168933250

This notification MUST be present at all times at the asbestos project sit

***** EMERGENCY NOTICE *****

Quantity to be removed: 234 Square Feet 0 Linear Feet Workshift days: W

Project starting date: 1/8/2025 Project Completion date: 1/8/2025 Workshift hours: 8-4

Site Name: W379_SarkinenRestoration_5413N Site address: 5413 NE 112th Cir. Vancouver WA 98686

Location of Asbestos: Kitchen, Dining room, Laundry room City/State/Zip: Vancouver WA 98686

Demolition of Structure (Notification of Demolition required) County: CLARK COUNTY

Asbestos survey conducted? No survey reason:

AHERA Inspector: Dustin Berry Certification #: IR-23-5437B

Material to be Removed:

Fireproofing Popcorn Ceiling CAB Sheet Vinyl Boiler Insulation Duct Tape

Duct Paper Mag Pipe Insulation Air Cell CA Pipe VAT

Other

Control Methods:

N.P Enclosure Glove Bag Mini Enclosure Wrap and Cut Water HEPA Vac

Other 6-Mil Poly, Wet, Labeled

Asbestos Contractor: Alpine Abatement Associates Inc. Phone: 541-388-2672

Mailing Address: PO Box 1557, Bend, OR, 97709 Email: annmarie@alpineabatement.com

Certification ##: ABCN00001215

Supervisor: Manuel Lopez Phone: 541-388-2672

Property Owner: Vickie & Delton Crowe Phone: 503-573-4086

Mailing Address: 5413 NE 112th Cir., Vancouver WA 98686

Asbestos Disposal Site: Hillsboro Landfill: 3205 SE Minter Bridge Rd, Hillsboro, OR, 97123-

I DO HEREBY CERTIFY THAT THE INFORMATION CONTAINED IN THIS NOTIFICATION IS, TO THE BEST OF MY KNOWLEDGE, ACCURATE AND COMPLETE.

Submitter Name: Bo Davidson

Representing: Alpine Abatement

Submitter Title: VP Operations

Date Submitted: 1/7/2025

Reviewed by SWCAA: Brian Fallon

Approved



11815 NE 99th Street, Suite 1294
Vancouver, WA 98662
Voice: 360-574-3058
Fax: 360-576-0925
Web: <https://www.swcleanair.gov>
Email: Tina@swcleanair.gov

Notice of Intent to Remove Asbestos

Case #: 25-019

Amendment: 0

Date Received: 1/7/2025

Date Paid: 1/7/2025

SWCAA Fee: \$768.00

Receipt #: 168933250

This notification MUST be present at all times at the asbestos project sit



CHAIN OF CUSTODY

Name / Company Name: Sarkinen / Dustin Kelly Phone: 360-253-4063
 Contact Email: Results@sarkinenrestoration.com
 Job Name: Vickie Crowe Job / Project:
 Address / Project Location: 5413 NE 112th Cir Vancouver wa 98686

Please check box that applies

Please check box that applies

Rush Samples turned in by 2PM will be processed the same day
 Next Day
 2-Day
 5-Day

Asbestos PLM
 Lead Paint
 Other

#	Material Description	Sample Location	Office Use Only
	Drywall	Dining Rm	
	Drywall	Kitchen	

Special Instructions:

Client Sign Here: *[Signature]* Date: 12-26- Time: 12:03
Atlas: Accepted By: *[Signature]* Date: 12/26/24 Time: 12:33pm
 Credit Card: Cash Check # Amount: \$
Lab Results Completed By: *[Signature]* Date Sent Out: 12/26/24 Email/Mail

*Atlas charges a per sample fee and not by layer. One sample fee equals four layers. Additional layers will result in an additional sample fee.



Batch # 2022 *

2448401

Analysis Date *

12/26/2024

Project #

Name / Company *

Dustin Berry

Project Name

Vickie Crowe

PO #

Analyst *

Crossland Kapaun

Project Location *

5413 NE 112th Cir.,
Vancouver, WA
98686

Turnaround Time *

Rush

Asbestos Analysis of Bulk Material by Polarized Light Microscopy

Sample*	Layer*	Description*	Non Asbestos*	Asbestos Type*	Asbestos %*
1	1	Drywall (White) - Dining Rm	Cellulose	None Present	N/D
1	2	Texture (White) - Dining Rm	Cellulose	Chrysotile	3%
2	1	Drywall (White) - Kitchen	Cellulose	None Present	N/D
2	2	Texture (White) - Kitchen	Cellulose	Chrysotile	3%

To Be Filled by the Technician

Technician *

Atlas Laboratories maintains liability to cost of analysis. This report relates only to the samples reported and may not be reproduced, except in full without written permission by Atlas. Atlas bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of

test results are the responsibility of the client. This report must not be used by the client to claim product certification, approval or endorsement by NVLAP, NIST, NIOSH or any other agency of the federal government. Non-friable organically bound materials present a problem matrix and therefore Atlas recommends gravimetric reduction prior to analysis. Samples received in good condition unless otherwise noted. Transmission Electron Microscopy asbestos identification and lead paint analysis will be available and performed by laboratories by proxy. Original analysis documents are available upon request of the client.

CHAIN OF CUSTODY

Name / Company Name: <u>Sarviner</u>	Phone: <u>360-253-4663</u>
Contact Email: <u>Results@Sarvinerrestoration.com</u>	
Job Name: <u>Vickie Crowe</u>	Job / Project:
Address / Project Location: <u>5413 NE 112th Cir, Vancouver wa 98686</u>	

Please check box that applies

Please check box that applies

- Rush Samples turned in by 2PM will be processed the same day
- Next Day
- 2-Day
- 5-Day

- Asbestos PLM
- Lead Paint
- Other

#	Material Description	Sample Location	Office Use Only
	<u>Vinyl</u>	<u>Laundry</u>	
	<u>Vinyl</u>	<u>kitchen 1</u>	
	<u>Vinyl</u>	<u>kitchen 2</u>	

Special Instructions:

Client Sign Here: <u>[Signature]</u>		Date: <u>1-7-25</u>	Time: <u>9:11 Am</u>
Atlas: Accepted By: <u>Kelly Katona</u>		Date: <u>01-07-2025</u>	Time: <u>9:12</u>
Credit Card:	Cash:	Check #	Amount: \$
Lab Results Completed By: <u>H. Mathews</u>		Date Sent Out: <u>1/7/25</u>	Email/Mail

*Atlas charges a per sample fee and not by layer. One sample fee equals four layers. Additional layers will result in an additional sample fee.



Batch # 2022 *

22-1744901

Analysis Date *

01/07/2025

Project #

Name / Company *

Dustin Berry/Sarkinen

Project Name

Vickie Crowe

PO #

Analyst *

Katherine Mathews

Project Location *

5413 NE 112th Cir.,
Vancouver, WA 98686

Turnaround Time *

Rush

Asbestos Analysis of Bulk Material by Polarized Light Microscopy

Sample*	Layer*	Description*	Non Asbestos*	Asbestos Type*	Asbestos %*
1	1	Vinyl (Beige / Light Green) - Laundry	Cellulose	Chrysotile	25%
1	2	Mastic (Tan) - Laundry	Cellulose	Chrysotile	2%
2	1	Vinyl (Green / Yellow) - Kitchen 1	Cellulose	Chrysotile	25%
3	1	Vinyl Tile (Beige) - Kitchen 2	Cellulose / Synthetic	None Present	N/D
3	2	Mastic (Clear) - Kitchen 2	Cellulose	Chrysotile	< 1%
3	3	Residual Vinyl Backing (Grey) - Kitchen 2	Cellulose	Chrysotile	40%

To Be Filled by the Technician

Technician *

K. Mathews

Atlas Laboratories maintains liability to cost of analysis. This report relates only to the samples reported and may not be reproduced, except in full without written permission by Atlas. Atlas bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. This report must not be used by the client to claim product certification, approval or endorsement by NVLAP, NIST, NIOSH or any other agency of the federal government. Non-friable organically bound materials present a problem matrix and therefore Atlas recommends gravimetric reduction prior to analysis. Samples received in good condition unless otherwise noted. Transmission Electron Microscopy asbestos identification and lead paint analysis will be available and performed by laboratories by proxy. Original analysis documents are available upon request of the client.