

**Southwest Clean Air Agency**

5101 NE 82nd Ave., Ste. 102

Phone: (360) 574-3058

**For Agency Use Only**

SWCAA ID: \_\_\_\_\_

Reviewed by: \_\_\_\_\_

Date: \_\_\_\_\_

☐ Passed ☐ Failed**TP-201.1C  
Drop Tube/Drain Valve Assembly Data Sheet**

|                                     |                                           |            |
|-------------------------------------|-------------------------------------------|------------|
| Station Name:                       | Test Company:                             | Test Date: |
| Address:                            | Test Personnel:                           |            |
| City, State, Zip:                   | Spill Container Make & Model:             |            |
| Date of Last Flowmeter Calibration: | Date of Last Pressure Device Calibration: |            |

**Test Results**

| Product Grade /<br>Tank ID | Time to Pressurize <sup>1</sup><br>(Must be under 5<br>min.) | N <sub>2</sub> Flow Rate Required to<br>Stabilize Pressure For 30<br>Seconds <sup>2</sup><br>(CFH) | Stabilized Pressure <sup>3</sup><br>(in. H <sub>2</sub> O) |
|----------------------------|--------------------------------------------------------------|----------------------------------------------------------------------------------------------------|------------------------------------------------------------|
|                            |                                                              |                                                                                                    |                                                            |
|                            |                                                              |                                                                                                    |                                                            |
|                            |                                                              |                                                                                                    |                                                            |
|                            |                                                              |                                                                                                    |                                                            |
|                            |                                                              |                                                                                                    |                                                            |
|                            |                                                              |                                                                                                    |                                                            |

<sup>1</sup> Record the time required to achieve a pressure of 2.00" ± 0.05" w.c. Nitrogen flow rate must not exceed 0.17 CFH during this pressurization step.

<sup>2</sup> Record the nitrogen flow rate required to maintain the pressure at 2.00" ± 0.05" w.c.

<sup>3</sup> Record the pressure at which the nitrogen flow was stabilized for 30 seconds. The pressure should be close to 2.00" w.c.

|           |
|-----------|
| Comments: |
|           |
|           |
|           |
|           |
|           |

\* The passing criteria is a leak rate of less than 0.17 CFH at a pressure of 2.0" w.c.