



Southwest Clean Air Agency

11815 NE 99th Street, Suite 1294 • Vancouver, WA 98682-2322

(360) 574-3058 • Fax: (360) 576-0925

www.swcleanair.org

June 4, 2015

Mr. Mark Anders
Puget Sound Energy
239 Zandecki Road
Chehalis, WA 98532

Subject: Notification of Emergency Generator Engine Installation – Shop Generator (SUN-093)

Dear Mr. Anders:

The Southwest Clean Air Agency (SWCAA) received your Small Unit Notification (SUN) on May 18, 2015 for installation and operation of an emergency generator engine to power the shop at the Jackson Prairie facility at 239 Zandecki Road, Chehalis, WA. For administrative and tracking purposes SWCAA has assigned tracking number SUN-093 to this notification. This notification was filed in accordance with SWCAA 400-072 and applies to the installation of one emergency generator engine. The unit was identified as:

- (1) 88 bhp natural gas-fired Mitsubishi model G25LTA engine to drive a 55 kW Olympian model G55LTA generator set. The engine is EPA certified for stationary emergency use.

SWCAA has completed a review of your notification and the associated support information and has determined that the notification meets the requirements of SWCAA 400-072(2). Once installed, affected equipment must maintain compliance with the requirements of SWCAA 400-072(4)(c) "**Emergency service internal combustion engines**". A copy of the relevant SWCAA 400-072 section is attached for your information.

Be advised that emission units installed pursuant to SWCAA 400-072 are subject to source registration and periodic inspection. Registration fees for this equipment will be invoiced consistent with SWCAA 400-100.

If you need further assistance or have any questions regarding these matters, please contact me at (360) 574-3058 extension 130.

Sincerely,

Paul T. Mairose
Chief Engineer



SWCAA 400-072 Emission Standards for Selected Small Source Categories

[Statutory Authority: Chapter 70.94.141 RCW. Original adoption 09-21-056 filed 10/15/09, effective 11/15/09.]

(4) Source categories.

(c) Emergency service internal combustion engines.

- (i) **Applicability.** The provisions of this section apply to emergency service internal combustion engines with a rating of less than 1,000 horsepower (e.g., emergency generators, fire pumps, sewer lift stations, etc.).
- (ii) **Emission limits and standards.**
 - (A) Visible emissions from diesel fired engine exhaust stacks shall not exceed ten percent opacity for more than 3 minutes in any one hour period as determined in accordance with SWCAA Method 9 (See SWCAA 400, Appendix A). This limitation shall not apply during periods of cold start-up.
- (iii) **General requirements.**
 - (A) Liquid fueled engines shall only be fired on #2 diesel or biodiesel. Fuel sulfur content of liquid fuels shall not exceed 0.0015% by weight (15 ppmw). A fuel certification from the fuel supplier may be used to demonstrate compliance with this requirement.
 - (B) Gaseous fueled engines shall only be fired on natural gas or propane.
 - (C) Each compression ignition engine shall be EPA Tier certified and manufactured no earlier than January 1, 2008.
 - (D) Engine operation shall be limited to maintenance checks, readiness testing, and actual emergency use.
 - (E) Engine operation for maintenance checks and readiness testing shall not exceed 100 hours per year. Total engine operation shall not exceed 200 hours per year.
 - (F) Each engine shall be equipped with a nonresettable hourmeter for the purpose of documenting hours of operation.
 - (G) Engine exhaust shall be discharged vertically. Any device that obstructs or prevents vertical discharge is prohibited.
- (iv) **Monitoring and recordkeeping requirements.** The information listed below shall be recorded at the specified intervals, and maintained in a readily accessible form for a minimum of 3 years. With the exception of data logged by a computerized data acquisition system, each required record shall include the date and the name of the person making the record entry.
 - (A) Total hours of operation for each engine shall be recorded annually;
 - (B) Fuel sulfur certifications shall be recorded for each shipment of liquid fuel;
 - (C) Maintenance activities shall be recorded for each occurrence consistent with the provisions of 40 CFR 60.4214;
 - (D) Upset conditions that cause excess emissions shall be recorded for each occurrence; and
 - (E) All air quality related complaints received by the permittee and the results of any subsequent investigation or corrective action shall be recorded for each occurrence.
- (v) **Testing requirements.** None.

(vi) **Reporting requirements.**

- (A) All air quality related complaints received by the owner or operator shall be reported to SWCAA within three calendar days of receipt.
- (B) The owner or operator of an affected emergency engine shall report the following information to the Agency no later than March 15th for the preceding calendar year:
 - (I) Hours of engine operation; and
 - (II) Air emissions of criteria air pollutants, VOCs, and toxic air pollutants (TAPs).

Summary Information (by SWCAA) for SUN-093
Puget Sound Energy – Jackson Prairie
Shop Emergency Generator

SUN-093 was submitted on May 18, 2015 for installation of a 55 kW natural gas-fired emergency generator set to supply emergency power to the shop. The following equipment details were available:

Location:	PSE – Jackson Prairie Storage Operations, 239 Zandecki Rd., Chehalis, WA 98532
Engine Make / Model:	Ford / G55LTA
Engine Family:	DGNXB05.42NN
Engine Serial Number:	GXB02671
Fuel:	Natural Gas
Fuel Consumption:	756 ft ³ /hr per hour at full standby load
Horsepower Rating:	88 hp at full generator standby on NG (82 hp nameplate)
Installation Date:	January 2014 – June 2015
Engine Built (Date):	September 30, 2013
Engine Certification:	EPA 2013 standards for stationary emergency
Generator Set Make / Model:	Olympian / G55LTA
Generator Set Output:	55 kW
Stack Description:	Not provided 414 acfm at 800°F
Applicable Federal Regulations:	40 CFR 60 Subpart JJJJ 40 CFR 63 Subpart ZZZZ

Shop Emergency Generator Engine. Potential annual emissions from the combustion of natural gas were calculated with the assumption that the equipment will operate at full load for up to 200 hours per year.

Shop Emergency Generator Engine			4-stroke rich-burn engine		
Hours per Year of Operation =			200 hours		
Power Output =			88 bhp		
Natural Gas Consumption Rate =			756 cubic feet per hour (Olympian)		
Natural Gas Heat Content =			1,020 Btu/scf for AP-42 emission factors		
Natural Gas Heat Content =			1,028 Btu/scf for 40 CFR 98 GHG emission factors		
	Emission	Emission			
	Factor	Factor			
Pollutant	g/hp-hr	lb/MMBtu	lb/hr	tpy	Emission Factor Source
NO _x	2.52	0.63	0.49	0.049	Olympian
CO	95.32	23.98	18.49	1.85	Olympian
VOC	1.60	0.40	0.31	0.031	Olympian (THC)
SO _x as SO ₂		0.0006	0.0005	0.00005	AP-42 Sec 3.2 (7/00)
PM		0.0095	0.0073	0.00073	AP-42 Sec 3.2 (7/00)
PM ₁₀		0.0095	0.0073	0.00073	AP-42 Sec 3.2 (7/00)
PM _{2.5}		0.0095	0.0073	0.00073	AP-42 Sec 3.2 (7/00)
1,1,2,2-Tetrachloroethane		0.0000253	2.0E-05	2.0E-06	AP-42 Sec 3.2 (7/00)
Acetaldehyde		0.00279	2.2E-03	2.2E-04	AP-42 Sec 3.2 (7/00)
Acrolein		0.00263	2.0E-03	2.0E-04	AP-42 Sec 3.2 (7/00)
Benzene		0.00158	1.2E-03	1.2E-04	AP-42 Sec 3.2 (7/00)
Formaldehyde		0.0205000	1.6E-02	1.6E-03	AP-42 Sec 3.2 (7/00)
Methylene Chloride		0.0000412	3.2E-05	3.2E-06	AP-42 Sec 3.2 (7/00)
Toluene		0.000558	4.3E-04	4.3E-05	AP-42 Sec 3.2 (7/00)
Xylene		0.000195	1.5E-04	1.5E-05	AP-42 Sec 3.2 (7/00)
TAP/HAP Total =				0.0022	
CO ₂ e					
Greenhouse Gases	kg/MMBtu	GWP	lb/MMBtu	tpy, CO ₂ e	Emission Factor Source
CO ₂	61.71	1	136.05	10.6	40 CFR 98
CH ₄	0.003	25	0.165	0.01	40 CFR 98
N ₂ O	0.0006	298	0.394	0.03	40 CFR 98
Total GHG - CO ₂ e				10.62	