



November 5, 2020

Mark Herceg  
City of Battle Ground  
109 SW 1<sup>st</sup> Street, STE 122  
Battle Ground, WA 98604

Subject: Notification of Emergency Generator Installation - City Hall (SUN – 249)

Dear Mr. Herceg:

The Southwest Clean Air Agency (SWCAA) received your Small Unit Notification (SUN) on October 30, 2020 for installation and operation of an emergency generator engine at the Battle Ground City Hall at 109 SW 1<sup>st</sup> Street., Battle Ground, WA. For administrative and tracking purposes SWCAA has assigned tracking number SUN-249 to this notification. This notification was filed in accordance with SWCAA 400-072 and applies to the installation of one emergency generator engine. The new unit was identified as:

- (1) 385 brake horsepower diesel-fired John Deere model 6090HF484B engine to drive a 255 kW Kohler generator set. The engine is EPA Tier 3 certified for stationary emergency use.

SWCAA has completed a review of your notification and the associated support information and has determined that the notification meets the requirements of SWCAA 400-072(2). Once installed, affected equipment must maintain compliance with the requirements of SWCAA 400-072(5)(c) "**Emergency service internal combustion engines.**" A copy of the relevant SWCAA 400-072 section is attached for your information.

Be advised that emission units installed pursuant to SWCAA 400-072 are subject to source registration and periodic inspection. Registration fees for this equipment will be invoiced consistent with SWCAA 400-100.

If you need further assistance or have any questions regarding these matters, please contact me at (360) 574-3058 extension 130.

Sincerely,

Paul T. Mairose  
Chief Engineer



## SWCAA 400-072 Emission Standards for Selected Small Source Categories

[Statutory Authority: Chapter 70.94.141 RCW. Original adoption 09-21-056 filed 10/15/09, effective 11/15/09, 16-19-009 filed 9/8/16, effective 10/9/16; 17-11-078 filed 5/18/17, effective 6/18/17; 20-06-003 filed 2/19/20, effective 3/21/20]

### (5) Source categories.

#### (c) Emergency service internal combustion engines.

- (i) **Applicability.** The provisions of this section apply to emergency service internal combustion engines with a rating of 50 or more, but less than 1,000 horsepower (e.g., emergency generators, fire pumps, sewer lift stations, etc.).
- (ii) **Emission limits and standards.**
  - (A) Visible emissions from diesel fired engine exhaust stacks shall not exceed ten percent opacity for more than 3 minutes in any one hour period as determined in accordance with SWCAA Method 9 (See SWCAA 400, Appendix A). This limitation shall not apply during periods of cold start-up.
- (iii) **General requirements.**
  - (A) Liquid fueled engines shall only be fired on #2 diesel or biodiesel. Fuel sulfur content of liquid fuels shall not exceed 0.0015% by weight (15 ppmw). A fuel certification from the fuel supplier may be used to demonstrate compliance with this requirement.
  - (B) Gaseous fueled engines shall only be fired on natural gas or propane.
  - (C) Each compression ignition engine shall be EPA Tier certified and manufactured no earlier than January 1, 2008.
  - (D) Engine operation shall be limited to maintenance checks, readiness testing, and actual emergency use.
  - (E) Engine operation for maintenance checks and readiness testing shall not exceed 100 hours per year. Actual emergency use is unrestricted.
  - (F) Each engine shall be equipped with a nonresettable hourmeter for the purpose of documenting hours of operation.
  - (G) Engine exhaust shall be discharged vertically. Any device that obstructs or prevents vertical discharge is prohibited.
- (iv) **Monitoring and recordkeeping requirements.** The information listed below shall be recorded at the specified intervals and maintained in a readily accessible form for a minimum of 3 years. With the exception of data logged by a computerized data acquisition system, each required record shall include the date and the name of the person making the record entry.
  - (A) Total hours of operation for each engine shall be recorded annually;
  - (B) Hours of emergency use for each engine shall be recorded annually;
  - (C) Fuel sulfur certifications shall be recorded for each shipment of liquid fuel;
  - (D) Maintenance activities shall be recorded for each occurrence consistent with the provisions of 40 CFR 60.4214;
  - (E) Upset conditions that cause excess emissions shall be recorded for each occurrence; and
  - (F) All air quality related complaints received by the permittee and the results of any subsequent investigation or corrective action shall be recorded promptly after each occurrence.
- (v) **Testing requirements.** None.

- (vi) **Reporting requirements.**
- (A) The owner or operator of an affected emission unit shall provide written notification of initial operation to SWCAA within 10 days of occurrence.
  - (B) All air quality related complaints received by the owner or operator shall be reported to SWCAA within three calendar days of receipt.
  - (C) The owner or operator of an affected emergency engine shall report the following information to the Agency no later than March 15<sup>th</sup> for the preceding calendar year:
    - (I) Hours of engine operation; and
    - (II) Air emissions of criteria air pollutants, VOCs, and toxic air pollutants (TAPs).

**Summary Information (by SWCAA) for SUN-249  
City of Battle Ground – Public Works  
Battle Ground City Hall Emergency Generator Engine**

A 255 kW diesel-fired emergency generator set will be installed at City Hall. The City Hall does not currently have an emergency generator. The following equipment details were available:

Location:	109 SW 1 <sup>st</sup> Street, Suite 122 Battle Ground, WA 98604 West of the southwest corner of the building
Engine Make / Model:	John Deere / 6090HF484B
Engine Serial Number:	To be determined
Fuel:	Diesel
Fuel Consumption:	17.6 gallons per hour at 100% power rating
Engine Power Rating:	287 kW, 385 bhp
Installation Date:	Scheduled for January 2021
Engine Built (Date):	To be determined
Engine Certification:	EPA Tier 3
Generator Set Make / Model:	Kohler / 250REOZJE
Generator Set Output:	255 kW (standby)
Stack Description:	6" diameter, exhausting 7' 4" above grade and 6" above the enclosure. Stack flow 1,911 acfm at 1,157°F ~ 45°46'46.54"N, 122°32'22.57"W
Applicable Federal Regulations:	40 CFR 60 Subpart III 40 CFR 63 Subpart ZZZZ

City of Battle Ground City Hall Emergency Generator Engine. Potential annual emissions from the combustion of ultra-low sulfur diesel (<0.0015% sulfur by weight) were calculated with the assumption that the equipment will operate at full load for up to 200 hours per year.

<b>City of Battle Ground City Hall Emergency Generator Engine</b>						
Hours of Operation =	200 hours					
Power Output =	385 bhp					
Diesel Density =	7.206 pounds per gallon					
Fuel Sulfur Content =	0.0015 % by weight					
Fuel Consumption Rate =	17.6 gal/hr (from Kohler data sheet)					
Fuel Heat Content =	0.138 MMBtu/gal (for use with GHG factors from 40 CFR 98)					
	Emission					
	Factor	Emissions	Emissions			
Pollutant	g/(bhp-hr)	lb/hr	tpy	Emission Factor Source		
NO <sub>x</sub>	2.60	2.21	0.221	South Coast AQMD Certification Data		
CO	0.70	0.59	0.059	South Coast AQMD Certification Data		
VOC	0.09	0.076	0.0076	South Coast AQMD Certification Data		
SO <sub>x</sub> as SO <sub>2</sub>		0.0038	0.00038	Mass Balance		
PM	0.11	0.093	0.0093	South Coast AQMD Certification Data		
PM <sub>10</sub>	0.11	0.093	0.0093	South Coast AQMD Certification Data		
PM <sub>2.5</sub>	0.11	0.093	0.0093	South Coast AQMD Certification Data		
			CO <sub>2</sub> e	CO <sub>2</sub> e		Emission Factor
Greenhouse Gases	kg/MMBtu	GWP	lb/MMBtu	lb/gallon	tpy, CO <sub>2</sub> e	Source
CO <sub>2</sub>	73.96	1	163.05	23	39.6	40 CFR 98
CH <sub>4</sub>	0.003	25	0.165	0.023	0.04	40 CFR 98
N <sub>2</sub> O	0.0006	298	0.394	0.054	0.10	40 CFR 98
Total GHG - CO <sub>2</sub> e			163.6	23	40	