

February 22, 2024

Dustin Harris, Maintenance Supervisor  
Clark Regional Wastewater – Whipple Creek West Regional Pump Station  
8000 NE 52<sup>nd</sup> Court  
Vancouver, Washington 98665

Subject: Notification of Emergency Generator Installation – Whipple Creek West Regional Pump Station (SUN – 313)

Dear Mr. Harris:

The Southwest Clean Air Agency (SWCAA) received your Small Unit Notification (SUN) on February 7, 2024, for installation and operation of an emergency generator engine at the Whipple Creek West Regional Pump Station. For administrative and tracking purposes SWCAA has assigned tracking number SUN-313 to this notification. This notification was filed in accordance with SWCAA 400-072 and applies to the installation of one emergency generator engine. The new unit was identified as:

208 bhp diesel-fired Cummins model QSB5-G6 engine to drive a 125 kW Cummins model C125D6C generator set. The engine is EPA tier 3 certified and meets the standards for stationary emergency engines.

SWCAA has completed a review of your notification and the associated support information and has determined that the notification meets the requirements of SWCAA 400-072(2). Once installed, affected equipment must maintain compliance with the requirements of SWCAA 400-072(5)(c) "**Emergency service internal combustion engines.**" A copy of the relevant SWCAA 400-072 section is attached for your information.

Be advised that emission units installed pursuant to SWCAA 400-072 are subject to source registration and periodic inspection. Registration fees for this equipment will be invoiced consistent with SWCAA 400-100.

If you need further assistance or have any questions regarding these matters, please contact me at (360) 574-3058 extension 131.

Sincerely,



Clinton Lamoreaux  
Chief Engineer

