

November 28, 2018

Derek Forsberg Williams Northwest Pipeline 295 Chipeta Way Salt Lake City, UT 84108

Re: Issuance of FINAL Title V Air Operating Permit SW98-7-R3

Dear Mr. Forsberg:

The Southwest Clean Air Agency (SWCAA) is issuing a final renewal Title V permit to Williams Northwest Pipeline - Washougal. The Title V permit will incorporate the requirements from the Boiler MACT Subpart DDDDD.

Copies of the final renewal Air Operating Permit and Title V Basis Statement accompany this letter. In addition, copies of the final permit will be available on SWCAA's website at www.swcleanair.org. If you have any questions or comments, please contact me at (360) 574-3058 ext. 129.

Sincerely,

WWW. 1 M Yaw ssa McClelland Vannessa McClelland Air Quality Engineer

Attachment

C: Part 70 Air Operating Permits U.S. EPA Region 10, Mail Stop: OAW-150 1200 Sixth Avenue, Suite 155 Seattle, WA 98101

Northwest Pipeline GP

Washougal Compressor Station

Air Operating Permit

SW98-7-R3

Final Permit Issued: November 28, 2018

Southwest Clean Air Agency 11815 NE 99th Street, Suite 1294 Vancouver, WA 98682 Telephone: (360) 574-3058

AIR OPERATING PERMIT #: SW98-7-R3

ISSUED TO:

Northwest Pipeline GP 295 Chipeta Way PO Box 58900

Salt Lake City, UT 84158-0900

PLANT SITE:

Northwest Pipeline GP

Washougal Compressor Station

1309 NE Brown Road Washougal, WA 98671

NATURE OF BUSINESS:

Natural Gas Compressor Station

SIC/NAICS:

4922/486210

AIRS NUMBER:

53-011-00144

EFFECTIVE DATE:

November 28, 2018

EXPIRATION DATE:

November 28, 2023

RENEWAL APPLICATION DUE:

June 1, 2023

PERMIT ENGINEER:

Vannessa McClelland, Air Quality Engineer

mabilale

Date

REVIEWED BY:

Paul T. Mairose, Chief Engineer

Date

APPROVED BY:

Uri Papish, Executive Director

Date

NORTHWEST PIPELINE GP

TABLE OF CONTENTS

I.	Abbreviations	3
II.	Regulatory Basis	4
III.	Emission Unit Identification	8
IV.	Permit Provisions	9
V.	General Terms and Conditions	13
VI.	Operating Terms and Conditions	16
VII.	Monitoring Terms and Conditions	20
VIII.	Recordkeeping Terms and Conditions	26
IX.	Reporting Terms and Conditions	28
X.	Non-Applicable Terms and Conditions	31
Apper	ndix A - Equivalent Source Test Method	A-1

I. ABBREVIATIONS

List of Common Abbreviations

Administrator EPA Region X Administrator

ADP Air Discharge Permit (aka Order of Approval)

AOP Air Operating Permit

BACT Best Available Control Technology CFR Code of Federal Regulations

CO Carbon monoxide

EPA U.S. Environmental Protection Agency

EU Emission unit

EU# Refers to a specific emission unit numbered "#"

FCAA Federal Clean Air Act

G# Refers to a specific general term and condition numbered "#"

g/hp-hr Grams per horsepower-hour gr/dscf Grains per dry standard cubic foot

HAP Hazardous air pollutant

hp Horsepower

IEU Insignificant emission unit

IEU# Refers to an insignificant emission unit numbered "#"

K# Refers to a specific recordkeeping requirement numbered "#"

lb/hr Pounds per hour

lb/MMBtu Pounds per million British thermal units

M# Refers to a specific monitoring requirement numbered "#"

MMBtu Million British Thermal Units

NSPS New Source Performance Standards (40 CFR 60)

NSR New source review NO_x Oxides of nitrogen

O₂ Oxygen

@ X% O₂ Corrected to X% oxygen content

P# Refers to a specific standard provision numbered "#"

PM Particulate matter

PM₁₀ Particulate matter less than 10 microns (μm) in diameter PM_{2.5} Particulate matter less than 2.5 microns (μm) in diameter

ppm Parts per million

ppmv Parts per million by volume

PTE Potential to emit

Refers to a specific reporting requirement numbered "#"

RACT Reasonably Available Control Technology

RCW Revised Code of Washington

Region 10 Region 10 of the U.S. Environmental Protection Agency

Req # Requirement number "#"

RMP Risk Management Plan under 40CFR Part 68

RPM Revolutions per minute SIP State Implementation Plan

SO₂ Sulfur dioxide

SWCAA Southwest Clean Air Agency

TAP Toxic air pollutants per WAC 173-460

tpy Tons per year

VOC Volatile organic compound
WAC Washington Administrative Code
WDOE Washington Department of Ecology

Terms not otherwise defined in this permit have the meaning assigned to them in the referenced regulations.

II. REGULATORY BASIS

This Air Operating Permit (AOP), hereafter referred to as the "Permit", is authorized under the procedures established in Washington Administrative Code (WAC) 173-401 and Title V (US Code §7661 et seq) of the Federal Clean Air Act (FCAA). As used in this Permit, "term", "condition", "standard", and "requirement" have the same meaning as "applicable requirement" specified under 40 Code of Federal Regulations (CFR) 70.2 and WAC 173-401-200.

The Permit is intended to contain a comprehensive list of the local, state, and federal air pollution regulations and standards applicable to the Permittee's facility and to assure and provide for certification of compliance with those requirements. Sections V through IX describe the applicable requirements and cite the originating local, state, or federal regulation or requirement. Federal requirements may be direct (e.g., FCAA or CFR citation) or established under the Washington State Implementation Plan (SIP). Each citation in the table also includes one or two effective dates of the cited regulation. Where there are two dates for the same regulatory citation, the underlying requirement is substantially the same, but the date of the regulation used for enforcement purposes would be different (e.g., federally enforceable versus SWCAA enforceable).

SWCAA is the primary authority that can enforce all requirements – federal, state, and local requirements – listed in the Permit. However, EPA and private citizens may also take enforcement actions under the Permit for those requirements that are federally enforceable; federal regulations, regulations that have a SIP date, and terms of ADPs are federally enforceable. Rules, regulations, and permits that are not SIP approved or federally promulgated are not federally enforceable.

Federal Regulation
Version SWCAA Delegation
Federal Regulations (Federally Enforceable) Version

40 CFR 51	July 1, 2017	Not Delegated
40 CFR 52	July 1, 2017	Not Delegated
40 CFR 60 Subpart A	July 1, 2017	June 18, 2017
[§60.1 et seq]		
40 CFR 60 Subpart GG	July 1, 2017	June 18, 2017
[§60.330 et seq]		
40 CFR 60 Subpart KKKK	July 1, 2017	June 18, 2017
[§60.4300 et seq]		
40 CFR 61 Subpart A	July 1, 2017	June 18, 2017
[§61.01 et seq]		
40 CFR 61 Subpart M	July 1, 2017	June 18, 2017
[§61.140 et seq]		
40 CFR 63 Subpart A	July 1, 2017	June 18, 2017
[§63.1 et seq]		
40 CFR 63 Subpart ZZZZ	July 1, 2017	June 18, 2017
[§63.6580 et seq]		(Title V Only)

Federal Regulation Version

SWCAA Delegation

Federal Regulations	(Federally Enforceable)	Version
40 CFR 63 Subpart DDDDD [63.7480 et seq]	July 1, 2017	June 18, 2017
40 CFR 68	July 1, 2017	Not Delegated
40 CFR 82	July 1, 2017	Not Delegated

SWCAA has not been delegated authority by EPA for selected subparts of 40 CFR 60 or 40 CFR 63. All monitoring, reporting, or recordkeeping for those subparts that is required to be sent to the EPA Administrator shall be sent to both SWCAA and the EPA Administrator. Unless otherwise specified in the delegation agreement, once authority for specific subparts of 40 CFR 60, or 40 CFR 63 have been delegated to SWCAA by EPA, all monitoring, reporting, or recordkeeping that is required to be sent to the EPA Administrator shall only be sent to SWCAA.

WA State Regulations (Federally Enforceable) WA State Regulation Version

WAC 173-400-105(7)	July 1, 2016	July 1, 2016
WAC 173-400-117	December 29, 2012	July 1, 2016
WAC 173-400-171	July 1, 2016	July 1, 2016
WAC 173-400-700	April 1, 2011	July 1, 2016
WAC 173-401	_	March 5, 2016
WAC 173-441	_	March 1, 2015
WAC 173-476	July 1, 2016	July 1, 2016

SIP Regulation Version (Federally

Enforceable) SWCAA Regulations **SWCAA Regulation Version** WAC 173-460 1 February 14, 1994 October 9, 2016² SWCAA 400-030 June 18, 2017 October 9, 2016³ SWCAA 400-040(1) June 18, 2017 SWCAA 400-040(2) June 18, 2017 October 9, 2016 June 18, 2017 SWCAA 400-040(3) SWCAA 400-040(4) June 18, 2017 June 18, 2017 SWCAA 400-040(5) October 9, 2016 SWCAA 400-040(6) October 9, 2016 June 18, 2017 SWCAA 400-040(7) October 9, 2016 June 18, 2017

-

The citation is a local-only adopted version of the state rule WAC 173-460 as adopted on February 14, 1994.

The citation does not include second sentence in SWCAA 400-030(21) and 400-030(129).

The citation does not include SWCAA 400-040(1)(c) and (d).

SIP Regulation Version (Federally

SWCAA Regulations	Enforceable)	SWCAA Regulation Version
SWCAA 400-040(8)	October 9, 2016	June 18, 2017
SWCAA 400-050(1)	October 9, 2016	June 18, 2017
SWCAA 400-050(2)	October 9, 2016	June 18, 2017
SWCAA 400-050(3)	_	June 18, 2017
SWCAA 400-060	October 9, 2016	June 18, 2017
SWCAA 400-070	October 9, 2016 ⁴	June 18, 2017
SWCAA 400-072	October 9, 2016	June 18, 2017
SWCAA 400-075		June 18, 2017
SWCAA 400-076	_	June 18, 2017
SWCAA 400-081	October 9, 2016	June 18, 2017
SWCAA 400-091	October 9, 2016	June 18, 2017
SWCAA 400-100		June 18, 2017
SWCAA 400-101	_	June 18, 2017
SWCAA 400-103		June 18, 2017
SWCAA 400-105	October 9, 2016 ⁵	June 18, 2017
SWCAA 400-106	October 9, 2016 ⁶	June 18, 2017
SWCAA 400-107	September 21, 1995	June 18, 2017
SWCAA 400-109	October 9, 2016 ⁷	June 18, 2017
SWCAA 400-110	October 9, 2016 8	June 18, 2017
SWCAA 400-113	October 9, 2016 9	June 18, 2017
SWCAA 400-114	October 9, 2016	June 18, 2017
SWCAA 400-115	_	June 18, 2017
SWCAA 400-116	October 9, 2016	June 18, 2017
SWCAA 400-120	_	June 18, 2017
SWCAA 400-130	_	June 18, 2017
SWCAA 400-131	October 9, 2016	June 18, 2017
SWCAA 400-136	October 9, 2016	June 18, 2017
SWCAA 400-151	October 9, 2016	June 18, 2017
SWCAA 400-161		June 18, 2017

Note that the SIP approved version of SWCAA 400-070 does not include 400-070(2)(a), 400-070(3)(b), 400-070(5), 400-070(6), 400-070(7), 400-070(8)(c), 400-070(9), 400-070(10), 400-070(11), 400-070(12), 400-070(14), and 400-070(15)(c).

11/28/18

The citation does not include reporting requirements related to WAC 173-460 or toxic air pollutants, not otherwise identified as HAPs.

The citation does not include SWCAA 400-106(1)(d)–(g) and 400-106(2).

The citation does not include the toxic air pollutant emissions thresholds in SWCAA 400–109(3)(d), 400–109(3)(e)(ii), and 400–109(4).

The citation does not include SWCAA 400-110(1)(d).

The citation does not include SWCAA 400-113(5).

SIP Regulation Version (Federally

SWCAA Regulations	Enforceable)	SWCAA Regulation Version	
SWCAA 400-171	October 9, 2016 10	June 18, 2017	
SWCAA 400-200	October 9, 2016 11	June 18, 2017	
SWCAA 400-205	October 9, 2016	June 18, 2017	
SWCAA 400-270	October 9, 2016	June 18, 2017	
SWCAA 425		June 18, 2017	
SWCAA 476	WCAA 476 — June 18, 2017		
SWCAA 400, Appendix A	October 9, 2016	June 18, 2017	

The following table lists the currently active ADPs, issued by SWCAA under a federally-approved new source review program, that apply to the facility; the terms of the ADPs are federally enforceable through the Title V Permit, unless the underlying regulatory authority does not have a federally enforceable date as specified in the tables above.

Minor New Source Review Parmit

Permit	Effective Date
SWCAA ADP 05-2596	February 2, 2006

The citation does not include SWCAA 400–171(2)(a)(xii).

The citation does not include SWCAA 400-200(1).

III. EMISSION UNIT IDENTIFICATION

Emission Unit	Unit Name	Unit Description This part of the Court Processor models
EU-1	Reciprocating Engine	This unit is a natural gas fired Cooper-Bessemer model 12/14V250C2, engine number 47862, turbocharged 12-cylinder, two cycle reciprocating engine-driven compressor rated at 4,000-hp, equipped with CleanBurn TM technology. It is used to drive a compressor which provides pressure in natural gas transmission lines. Torque and RPM can be varied based on demand with emissions varying accordingly.
EU-2	Turbine	This unit is a Solar Turbines, Inc. Taurus 60-T7800S (SOLONOX), gas turbine rated at 7,800-hp output. Natural gas from the pipeline is run through the turbine compressor which provides pressure in natural gas transmission lines.
EU-3	Boiler	This unit is a Sellers model C60W, serial number 100553 (front plate), natural gas fired process heater (boiler) with a heat input rate of 2.5 MMBtu per hour. It is used to produce hot water for process heating. This unit is 40 CFR 63 Subpart DDDDD applicable and is designated as a Gas 1 subcategory.
EU-4	Generator Engine	This unit is a Caterpillar 452 KW, 606-hp, generator model SR4, engine model 3412 STD, engine number 7DB01091, emergency electrical generator which is natural gas fired. It is used to provide emergency electrical power during power outages. This unit is 40 CFR 63 Subpart ZZZZ applicable.
EU-5	Fire Pump Engine	This unit is a Detroit Diesel-Allison, Inc diesel fire pump, 80-hp model PDFP 04YT2502 serial number U693769A manufactured in August 1995. It is used to provide water a hydrant used by the fire department. This unit is 40 CFR 63 Subpart ZZZZ applicable.

IV. PERMIT PROVISIONS

40 CFR 51.212 40 CFR 52.12, 40 CFR 52.33 40 CFR 60.11, 40 CFR 60.12

P1. Credible Evidence

For the purposes of submitting compliance certifications or establishing whether a violation of any term or condition of this Permit has occurred or is occurring, nothing shall preclude the use, including the exclusive use, of any credible evidence or information, relevant to whether the Permittee would have been in compliance with a specific term or condition if the appropriate performance or compliance test or procedure would have been performed.

WAC 173-401-500(5) WAC 173-401-620(2)(e) SWCAA 400-270

P2. Confidentiality of Records and Information

The Permittee is responsible for clearly identifying information that is considered proprietary and confidential prior to submittal to SWCAA. Requests for proprietary and confidential information shall be released only after legal opinion by SWCAA's legal counsel, and notice to the Permittee of the intent to release or deny the release of information.

In the case where the Permittee has submitted information to SWCAA under a claim of confidentiality, SWCAA may also require the source to submit a copy of such information directly to the EPA Administrator.

Upon request, the Permittee shall also furnish to the permitting authority copies of records required to be kept by the Permittee or, for information claimed to be confidential, the Permittee may furnish such records directly to the EPA Administrator along with a claim of confidentiality. Permitting authorities shall maintain confidentiality of such information in accordance with RCW 70.94.205.

P3. Insignificant Emission Unit - Permit Revision

WAC 173-401-530(6)

Any emissions unit or activity that qualifies as insignificant solely on the basis of provisions in WAC 173-401-530(1)(a) shall not exceed the emissions thresholds specified in WAC 173-401-530(4) until this Permit is modified pursuant to WAC 173-401-725.

P4. Permit Duration

WAC 173-401-610

This Permit shall be valid for a fixed term of 5 years.

 P5.
 Standard Provisions
 SWCAA 400-103

 WAC 173-401-620(2)
 WAC 173-401-620(2)

- (a) Duty to comply. The Permittee must comply with all conditions of this Chapter 401 Permit. Any Permit noncompliance constitutes a violation of Revised Code of Washington (RCW) Chapter 70.94 and, for federally enforceable provisions, a violation of the FCAA. Such violations are grounds for enforcement action; for Permit termination, revocation and reissuance, or modification; or for denial of a Permit renewal application.
- (b) Need to halt or reduce activity not a defense. It shall not be a defense for a Permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this Permit.
- (c) Permit actions. This Permit may be modified, revoked, reopened, and reissued, or terminated for cause. The filing of a request by the Permittee for a Permit modification,

- revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any Permit condition.
- (d) *Property rights*. This Permit does not convey any property rights of any sort, or any exclusive privilege.
- (e) Duty to provide information. The Permittee shall furnish to the permitting authority, within a reasonable time, any information that the permitting authority may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the Permit, or to determine compliance with the Permit. Upon request, the Permittee shall also furnish to the permitting authority copies of records required to be kept by the Permittee or, for information claimed to be confidential, the Permittee may furnish such records directly to the Administrator along with a claim of confidentiality. Permitting authorities shall maintain confidentiality of such information in accordance with RCW 70.94.205.
- (f) *Permit fees.* The Permittee shall pay fees in accordance with RCW 70.94.162 as a condition of this Permit in accordance with the permitting authority's fee schedule. Failure to pay fees in a timely fashion shall subject the Permittee to civil and criminal penalties as prescribed in RCW 70.94.430 and 70.94.431.
- (g) *Emission trading*. No Permit revision shall be required, under any approved economic incentives, marketable permits, emissions trading and other similar programs or processes for changes that are provided for in this Permit.
- (h) Severability. If any provision of this Permit is held to be invalid, all unaffected provisions of the Permit shall remain in effect and be enforceable.
- (i) Permit appeals. This Permit or any conditions in it may be appealed only by filing an appeal with the Pollution Control Hearings Board and serving it on the permitting authority within thirty days of receipt of the Permit pursuant to RCW 43.21B.310. This provision for appeal in this section is separate from and additional to any federal rights to petition and review under § 505(b) of the FCAA.
- (j) Permit continuation. This Permit and all terms and conditions contained herein shall not expire until the renewal Permit has been issued or denied if a timely and complete application has been submitted. An application shield granted pursuant to WAC 173-401-705(2) shall remain in effect until the renewal Permit has been issued or denied if a timely and complete application has been submitted.

P6. Federally Enforceable Requirements

WAC 173-401-625

- (a) All terms and conditions in this Permit, including any provisions designed to limit a source's potential to emit, are enforceable by EPA and citizens under the FCAA.
- (b) Notwithstanding the above, any terms and conditions included in this Permit that are not required under the FCAA or under any of its applicable requirements are not federally enforceable under the FCAA. Terms and conditions so designated are not subject to the EPA and affected states review requirements of WAC 173-401-700 through WAC 173-401-820. Terms that are SWCAA enforceable only are marked with "L".

P7. Permit Shield

WAC 173-401-640

Compliance with the conditions of this Permit shall be deemed compliance with all applicable requirements that are specifically identified in this Permit as of the date of permit issuance. Nothing in this Permit shall alter or affect the following:

(a) The provisions of Section 303 of the FCAA (emergency orders), including the authority of the Administrator under that section;

- The liability of an owner or operator of a source for any violation of applicable requirements prior to or at the time of permit issuance;
- The applicable requirements of the acid rain program, consistent with Section 408(a) of the FCAA:
- The ability of EPA to obtain information from a source pursuant to Section 114 of the (d) FCAA; and
- The ability of the permitting authority to establish or revise requirements for the use of (e) reasonably available control technology (RACT) as defined in RCW 70.94.030(19).

WAC 173-401-705(2)

Permit Expiration – Application Shield

WAC 173-401-710(3)

Permit expiration terminates the source's right to operate unless a timely and complete renewal application has been submitted consistent with WAC 173-401-710(1) and WAC 173-401-500. All terms and conditions of the Permit shall remain in effect after the Permit expires if a timely and complete Permit application has been submitted. Operation under the terms and conditions of the expired Permit will be allowed until SWCAA takes final action on the renewal application.

Permit Revocation

WAC 173-401-710(4)

SWCAA may revoke a Permit only upon the request of the Permittee or for cause. The permitting authority shall provide at least thirty days written notice to the Permittee prior to revocation of the Permit or denial of a Permit renewal application. Such notice shall include an explanation of the basis for the proposed action and afford the Permittee an opportunity to meet with the permitting authority prior to the authority's final decision. A revocation issued under this section may be issued conditionally with a future effective date and may specify that the revocation will not take effect if the Permittee satisfies the specified conditions before the effective date.

P10. Reopening for Cause

WAC 173-401-730

This Permit shall be reopened and revised under any of the following circumstances:

- Additional applicable requirements become applicable to a major air operating Permit source with a remaining Permit term of 3 or more years. Such a reopening shall be completed not later than 18 months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which the Permit is due to expire, unless the original Permit or any of its terms and conditions have been extended pursuant to WAC 173-401-620(2)(j);
- Additional requirements (including excess emissions requirements) become applicable to an affected source under the acid rain program. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the Permit;
- The Administrator or SWCAA determines that the Permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the Permit; or
- The Administrator or SWCAA determines that the Permit must be revised or revoked to assure compliance with the applicable requirements.

Proceedings to reopen and issue this Permit shall follow the same procedures as apply to initial permit issuance and shall affect only those parts of the Permit for which cause to reopen exists. Reopenings under this section shall not be initiated before a notice of such intent is provided to the AOP source by SWCAA. Such notice shall be made at least 30 days in advance of the date that the Permit is to be reopened, except that SWCAA may provide a shorter time period in the case of an emergency.

WAC 173-401-722 WAC 173-401-724

P11. Changes not Requiring Permit Revision/Off Permit Changes

The Permittee may make changes described in WAC 173-401-722 and WAC 173-401-724 without revising this Permit, provided that the changes satisfy the criteria set forth in those sections, including the requirements to notify SWCAA and EPA. Changes made by the Permittee under WAC 173-401-724 do not qualify for a Permit shield.

P12. Excess Emissions

SWCAA 400-107

The Permittee shall report excess emissions to SWCAA as soon as possible. Excess emissions due to startup or shutdown conditions or due to scheduled maintenance shall be considered unavoidable provided the source reports as required under by SWCAA 400-107(1) and adequately demonstrates that the excess emissions could not have been prevented or avoided.

Excess emissions due to upsets shall be considered unavoidable provided that the Permittee reports as soon as possible but no later than 48 hours after discovery, and adequately demonstrates that:

- (a) The event was not caused by poor or inadequate design, operation, or maintenance, or any other reasonably preventable conditions;
- (b) The event was not of a recurring pattern indicative of inadequate design, operation, or maintenance;
- (c) The operator took immediate and appropriate corrective action in a manner consistent with good air pollution control practice for minimizing emissions during the event, taking into account the total emissions impact of the corrective action, including slowing or shutting down the emission unit as necessary to minimize emissions, when the operator knew or should have known that an emission standard or Permit condition was being exceeded; and
- (d) The owner or operator(s) actions in response to the excess emissions were documented by properly signed, contemporaneous operating logs, or other relevant evidence.

This requirement does not apply to federal standards.

V. GENERAL TERMS AND CONDITIONS

40 CFR 61, Subpart M SWCAA 400-075

G1. Asbestos

SWCAA 476

The Permittee shall comply with the provisions of SWCAA 476 "Standards for Asbestos Control, Demolition and Renovation" when conducting any renovation, demolition, or asbestos storage activities at the facility.

G2. Chemical Accident Prevention Provisions

40 CFR 68

The Permittee shall comply with the requirements of the Chemical Accident Prevention Provisions at 40 CFR 68 no later than the latest of the following dates:

- Three years after the date on which a regulated substance, present above the threshold quantity in a process, is first listed under 40 CFR 68.130; or
- The date on which a regulated substance is first present above a threshold quantity in a process.

G3. Protection of Stratospheric Ozone 40 CFR 82, Subparts B & F
The Permittee shall comply with the standards for recycling and emissions reduction as provided in 40 CFR 82, Subparts B and F.

G4. Duty to Supplement or Correct Application WAC 173-401-500(6)

The Permittee, upon becoming aware that relevant facts were omitted or incorrect information was submitted in a Permit application, shall promptly submit such supplementary facts or corrected information. In addition, an applicant shall provide additional information as necessary to address any requirements that become applicable to the source after the date it filed a complete application but prior to release of a draft Permit.

40 CFR 63.6650(c)(2)

G5. Certification of Submittals

WAC 173-401-520

All application forms, reports, and compliance certifications must be certified by a responsible official. Certification shall state that, based on information and belief formed after reasonable inquiry, the statements and information contained in the submittal are true, accurate, and complete.

WAC 173-401-630(2)

G6. Inspection and Entry

SWCAA 400-105(2&3)

The Permittee shall allow inspection and entry, upon presentation of credentials and other documents as may be required by law, by the permitting authority or an authorized representative to perform the following:

- Enter upon the Permittee's premises where a Permit source is located or emissions-related activity is conducted, or where records must be kept under the conditions of the Permit;
- (b) Have access to and copy, at reasonable times, any records that must be kept under the conditions of the Permit:
- Inspect at reasonable times any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under the Permit; and
- As authorized by SWCAA 400-105 and the FCAA, sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the Permit or applicable requirements.

WAC 173-401-510(2)(h)(iii) WAC 173-401-630(3)

G7. Schedule of Compliance

The Permittee shall continue to comply with all applicable requirements with which the source is currently in compliance, and meet on a timely basis any applicable requirements that become effective during the Permit term.

G8. Permit Renewal Application

WAC 173-401-710(1)

The Permittee shall submit a complete Permit renewal application to SWCAA no later than the date established in the Permit. All terms and conditions of the Permit shall remain in effect after the Permit expires if a timely and complete Permit application has been submitted. Operation under the terms and conditions of the expired Permit will be allowed until SWCAA takes final action on the renewal application.

This Permit expires on November 28, 2023. A renewal application is due on November 28, 2022, one year prior to expiration, and a complete renewal application is due no later than June 1, 2023, 180 days prior to expiration.

Transfer of Ownership or Operational Control WAC 173-401-720(1)(d)

A change in Permittee due to transfer of ownership or operational control of an affected source requires a request for administrative permit amendment as governed by WAC 173-401-720(1)(d).

Portable Sources G10.

SWCAA 400-110(6)

Portable sources which locate temporarily at the facility shall be allowed to operate at the temporary location without filing an ADP application provided that:

- The source/emission units are registered with SWCAA; (a)
- (b) The source/emission units have an ADP to operate as a portable source or have an approved Permit that meets the requirements that meet SWCAA 400-036;
- (c) The owner(s) or operator(s) notifies SWCAA of the intent to operate at the new location at least ten business days prior to starting the operation;
- The owner(s) or operator(s) supplies sufficient information including production quantities (d) and hours of operation, to enable SWCAA to determine that the operation will comply with the emission standards for a new source, and will not cause a violation of applicable ambient air quality standards and, if in a nonattainment area, will not interfere with scheduled attainment of ambient standards; and
- Portable sources that do not have a valid ADP issued by SWCAA but do have a valid (e) approval issued by a Washington air pollution control authority after July 1, 2010, may operate within SWCAA jurisdiction without filing an ADP application pursuant to SWCAA 400-109 or obtaining an ADP pursuant to SWCAA 400-110 provided the requirements of SWCAA 400-036 are met.

Misrepresentation and Tampering

SWCAA 400-105(5&6)

- The Permittee shall not make any false material statement, representation or certification in (a) any form, notice, or report.
- The Permittee shall not render inaccurate any monitoring device or method required under (b) Chapter 70.94 RCW, or any ordinance, resolution, regulation, permit, or order in force pursuant thereto.

WAC 173-400-700 WAC 173-460 (*Local*) SWCAA 400-109, SWCAA 400-109 SWCAA 400-110

G12. New Source Review

The Permittee shall not construct or modify a source which is required to be reviewed under WAC 173-400-700, WAC 173-460 (effective 2/14/1994), or SWCAA 400-110 without first receiving an approval or Permit under such provisions. Portable sources may be exempt from this requirement if they fulfill the criteria described in G10. This requirement is not applicable to emission units that comply with the provisions of SWCAA 400-072.

G13. Replacement or Substantial Alteration of Emission Control

Technology at an Existing Stationary Source SWCAA 400-114

Prior to replacing or substantially altering emission control technology installed at an existing stationary source or emission unit, the Permittee shall file ADP application with SWCAA. Construction shall not commence on a project subject to review until SWCAA issues a Final ADP or other regulatory order. However, any ADP application filed under this section shall be deemed to be approved without conditions if SWCAA takes no action within 30 days of receipt of a complete application.

G14. Maintenance of Process Equipment

SWCAA 400-116(1)

Any process equipment, including features, machines, and devices constituting parts of or called for by plans, specifications, or other information submitted for approval or required as part of an approval shall be maintained and operate in good working order. SWCAA reserves the right to take any and all appropriate action to maintain compliance with approval conditions, including directing the facility to cease operations of defective or malfunctioning equipment until corrective action can be completed.

G15. Maintenance of Pollution Control Equipment

SWCAA 400-116(2)

Any equipment that serves as air contaminant control or capture equipment shall be maintained and operate in good working order at all times in accordance with good operations and maintenance practices and in accordance with SWCAA approval conditions. SWCAA reserves the right to take any and all appropriate action to maintain compliance with approval conditions, including directing the facility to cease operations of defective or malfunctioning equipment until corrective action can be completed.

G16. Outdoor Burning

SWCAA 425 (Local)

The Permittee is prohibited from conducting outdoor burning except as allowed by SWCAA 425.

G17. Reporting of Emissions of Greenhouse Gases

WAC 173-441 (State)

WAC 173-441 requires owners and operators of affected facilities to quantify and report emissions of greenhouse gases from applicable source categories listed in WAC 173-441-120. This regulation applies to any facility located in Washington State with total greenhouse gas emissions of ten thousand metric tons of carbon dioxide equivalent (CO₂e) or more per calendar year. The Permittee shall prepare and submit greenhouse gas reports to the Washington Department of Ecology in accordance with the provisions of WAC 173-441-050 for each affected facility.

VI. OPERATING TERMS AND CONDITIONS

The following table lists all federal, state, and local requirements applicable to the Permittee. The effective date for each applicable requirement is listed in Section II, which also describes the enforceability of the term. Those specific ADP requirements that are SWCAA enforceable only are denoted with "L". The legal authority for each requirement is listed below each requirement. Any requirement listed specified as "Plantwide" in the Emission Unit column, applies to all emission units or activities, regardless of whether identified as an EU or an IEU. Some of the requirements may have been fully or partially adopted into the Washington SIP, and are therefore federally enforceable. Requirements which are not required under the FCAA are State only or Local only requirements authorized under the WAC or SWCAA local regulations. Section II gives citations for the regulations and denotes whether they are federally, state, or locally enforceable. Monitoring requirements are used to provide a reasonable assurance of compliance with the applicable requirements and may or may not involve the use of a reference test method.

Req.#	Requirements	Emission Point	Monitoring
Req-1	NO _x emissions from the turbine shall not exceed 42 ppm corrected to 15% O ₂ . Reference Method – EPA Method 20 40 CFR 60.4320(a) – Subpart KKKK SWCAA 400-115	EU2	M1 NO _x Standard
Req-2	Permittee shall not burn any fuel which contains total potential sulfur emissions in excess of 26 ng SO ₂ /J (0.06 lb SO ₂ /MMBtu) heat input. Reference Method – ASTM D5287 40 CFR 60.4330(a)(2) – Subpart KKKK SWCAA 400-115	EU2	M2 Compliance Certification
Req-3	The turbine, air pollution control equipment, and monitoring equipment shall be operated in a manner consistent with good air pollution control practices for minimizing emissions at all times including during startup, shutdown and malfunction. 40 CFR 60.11(d) 40 CFR 60.4333(a) – Subpart KKKK SWCAA 400-115		M3 Turbine Monitoring
Req-4	The emergency generator may be operated for the purpose of maintenance checks and readiness testing, provided that the tests are recommended by the manufacturer, the vendor, or the insurance company associated with the engine. Required testing of such units should be minimized. 40 CFR 63.6640(f) – Subpart ZZZZ SWCAA 400-045	EU4	M4 Generator Monitoring
Req-5	The emergency generator may operate up to 50 hours per year in non-emergency situations in addition to the time operated for maintenance checks and readiness testing. 40 CFR 63.6640(f) – Subpart ZZZZ	EU4	M4 Generator Monitoring

Req.#	Requirements	Emission Point	Monitoring
Req-6	The permittee shall conduct the following maintenance for the fire pump: a. Change oil and filter every 1,000 hours of operation or annually, whichever comes first except as provided in 40 CFR 63.6625(i); b. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first; c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary; 40 CFR 63.6602 & Table 2c, Section 2 – Subpart ZZZZ 40 CFR 63.6625(e) — Subpart ZZZZ	EU5	M5 Fire Pump Engine Monitoring Plan
Req-7	At all times the fire pump must be operated and maintained in a manner consistent with safety and good air pollution control practices for minimizing emissions. 40 CFR 63.6625(e) & 40 CFR 63.6605(b) – Subpart ZZZZ	EU5	M5 Fire Pump Engine Monitoring Plan
Req-8	The Permittee shall minimize the time the fire pump spends at idle and minimize the fire pump's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes. 40 CFR 63.6625(h) – Subpart ZZZZ	EU5	N/A
Req-9	Permittee shall not cause or permit any emission which exceeds 20% opacity for more than three minutes (aggregate) in any one hour period except as provided in SWCAA 400-040(1). Reference Method – SWCAA Method 9 (SWCAA 400 App. A) SWCAA 400-040(1)		M6 Opacity Monitoring
Req-10	Permittee shall not cause or permit fallout of particulate matter beyond the source's property boundary in sufficient quantity to interfere unreasonably with use and enjoyment of the property on which the fallout occurs. SWCAA 400-040(2) (L)		M7 Fugitive Emissions Monitoring
Req-11	Permittee shall take reasonable precautions to prevent the release of air contaminants from any operation that emits fugitive emissions. SWCAA 400-040(3) ADP 05-2596, Condition 7		M7 Fugitive Emissions Monitoring
Req-12	Operations that cause or contribute to odors that unreasonably interfere with any other property owner's use and enjoyment of their property shall use recognized good practice and procedures to reduce those odors to a reasonable minimum. SWCAA 400-040(4) (L) ADP 05-2596, Condition 8	Plantwide	M7 Fugitive Emissions Monitoring
Req-13	Permittee shall not cause or permit the emission of any air contaminant detrimental to persons, property or business. SWCAA 400-040(5)	Plantwide	M8 Complaint Monitoring
Req-14	Permittee shall not cause or permit any emissions unit to emit a gas containing in excess of 1,000 ppm of sulfur dioxide on a dry basis, corrected to 7% O ₂ or 12% CO ₂ as required by the applicable emission standard for combustion sources, and based on the average of sixty (60) consecutive minutes. Reference Method – 40 CFR 60 Appendix A Method 6 SWCAA 400-040(6)	Plantwide	M2 Compliance Certification
Req-15	Permittee shall not cause or permit the installation or use of any means which conceals or masks an emission which would otherwise violate any provisions of SWCAA 400-040. SWCAA 400-040(7)	Plantwide	M2 Compliance Certification

Req.#	Requirements			Emission Point	Monitoring
Req-16	Permittee shall take reasonable precautions to prevent emissions of fugitive dust and operate the source to minimize emissions. SWCAA 400-040(8)(a) ADP 05-2596, Condition 7			Plantwide	M7 Fugitive Emission Monitoring
Req-17	Permittee shall not cause or permit emissions of particulate matter from a combustion or incineration emissions unit in excess of 0.1 gr/dscf of exhaust gas corrected to 7% oxygen. Reference Method – 40 CFR 60 Appendix A Method 5 SWCAA 400-050(1)&(3)			Plantwide	M6 Opacity Monitoring
Req-18	process unit in excess	of 0.1 gr/dscf of exhaust gas. OCFR 60 Appendix A Method 5 SWCAA 400-060	atter from a general	Plantwide	M6 Opacity Monitoring
Req-19	Combined emissions in Pollutant NOx CO VOCs SO2 PM Benzene Formaldehyde	From plant operations shall not exceed: Emission Limit 143.3 ton/yr 114.4 ton/yr 29.3 ton/yr 1.5 ton/yr 15.2 ton/yr 0.25 ton/yr 16.4 ton/yr ADP 05-2596, Condition 1		Plantwide	M9 Engine Testing, M10 Turbine Testing, M11 Boiler and Generator Limits
Req-20	Emissions from the re Pollutant NOx CO VOCs SO2 PM Benzene Formaldehyde * At 100% torque, 25	ciprocating engine shall not exceed the formula in the Emission Limit 3.0 grams/hp-hour* and 115.8 ton/yr 2.0 grams/hp-hour* and 77.2 ton/yr 0.5 grams/hp-hour* and 19.3 ton/yr 0.44 ton/yr 3.01 lb/hr and 13.2 ton/yr 0.056 lb/hr and 0.25 ton/yr 3.5 lb/hr and 15.3 ton/yr	Reference Method EPA Method 7E EPA Method 10 EPA Method 18 or 25A EPA Method 6 EPA Method 5 EPA Method 18 EPA Method 320	EU1	M9 Reciprocating Engine Testing and Recording Requirements
Req-21	Emissions from the tu Pollutant NOx CO VOCs SO2 PM Benzene Formaldehyde * At ≥ 90 percent NO	Emission Limit 25 ppmdv* @15% O ₂ and 28.37 ton/y 50 ppmdv* @15% O ₂ and 34.54 ton/y 25 ppmdv @15% O ₂ and 9.89 ton/yr 0.98 ton/yr 0.43 lb/hr and 1.87 ton/yr 6.4x10 ⁻⁴ lb/hr and 0.002 ton/yr 0.25 lb/hr and 1.08 ton/yr	or 20	EU2	M10 Turbine Testing and Recording Requirements M3 Turbine Monitoring

Req.#	Requirements				Monitoring
Dec 22	Emissions from the	e boiler shall not exceed the following:		EU3	M11 Boiler
Req-22	Pollutant	Emission Limit	Reference Method		and Generator
	NO _x	0.245 lb/hr and 1.07 ton/yr	EPA Method 7E		Engine
		•	or 20		Recording
	СО	0.206 lb/hr and 0.90 ton/yr	EPA Method 10		Requirements
	VOCs	0.014 lb/hr and 0.06 ton/yr	EPA Method 18		-
		•	or 25A		
	SO ₂	0.04 ton/yr	EPA Method 6		
	PM	0.019 lb/hr and 0.08 ton/yr	EPA Method 5		
		ADP 05-2596, Condition 4			
Req-23	Emissions from the	e emergency generator shall not exceed to		EU4	M11 Boiler
1104 25	<u>Pollutant</u>	Emission Limit	Reference Method		and Generator
	NO _x	10.2 lb/hr and 1.02 ton/yr	EPA Method 7E		Engine
			or 20		Recording
	СО	17.2 lb/hr and 1.72 ton/yr	EPA Method 10		Requirements
	VOCs	0.14 lb/hr and 0.01 ton/yr	EPA Method 18		
			or 25A		
	SO ₂	0.002 ton/yr	EPA Method 6		
	PM	0.090 lb/hr and 0.01 ton/yr	EPA Method 5		
	X7' '1 1 ' '	ADP 05-2596, Condition 5		7711 7714	1460
Req-24	Visible emissions shall not exceed five percent opacity for more than 3 minutes in		EU1-EU4	M6 Opacity	
	any one-hour period as determined in accordance with SWCAA Method 9 (See			Monitoring	
	Appendix A of SWCAA 400).				
	Reference Method – SWCAA Method 9 ADP 05-2596, Condition 6				
	All equipment sha		tal sulfur content of 20.0	Plantwide	M2
Req-25	All equipment shall be fired on natural gas only with a total sulfur content of 20.0 grains per 100 standard cubic feet or less.		i iantwide	Compliance	
	ADP 05-2596, Condition 10				Certification
	The regime seting	engine shall be maintained at levels	areator than ar aqual to	EU1	M12
Req-26				LUI	Reciprocating
	175 rpm on a one-hour average except during startup and shut down. ADP 05-2596, Condition 11			engine RPM	
		71D1 03-2370, Condition 11			and Torque
	The steels height a	of the regime entire and to-bine	shall not be less than 04	EU1, EU2	M2
Req-27		of the reciprocating engine and turbine			Compliance
	feet above ground level unless modeling is performed and approved by SWCAA				Certification
	that demonstrates compliance with all applicable regulations and standards at a lower stack height.			Continuation	
	lower stack neight.	ADP 05-2596, Condition 12			
D 20	Hours of operation	of the emergency generator shall not ex	ceed 200 hours per year	EU6	M11 Boiler
Req-28	Trouis or operation	ADP 05-2596, Condition 13	Leve 200 Hours per Jour.		and Generator
		1151 05 2570, Condition 15			Engine
					Recording
					Requirements

VII. MONITORING TERMS AND CONDITIONS

To assure compliance with all applicable requirements, the permittee shall perform the monitoring program specified below. These monitoring requirements also ensure that the equipment is being maintained as per 40 CFR 60.11(d) where applicable. Each monitoring requirement is indexed according to the underlying requirement(s). Pursuant to WAC 173-401-530(2)(c), none of the following monitoring requirements apply to IEUs.

The permittee shall make a record of all required monitoring activities as described in Section K1 of this permit.

M1. NO_x Standard

40 CFR 60.4320(a), SWCAA 400-115

This monitoring requirement applies to Req-1.

Compliance with the standard shall be demonstrated either by selecting one of the following three compliance options:

- (a) Periodic source testing as described in 40 CFR 60.4340(a). Source testing must be performed annually in accordance with 40 CFR 60.4400 to demonstrate continuous compliance. If the NO_x emission result from the performance test is less than or equal to 75 percent of the NO_x emission limit for the turbine, the permittee may reduce the frequency of subsequent performance tests to once every two years (no more than 26 calendar months following the previous performance test). If the results of any subsequent performance test exceeds 75 percent of the NO_x emission limit for the turbine, the permittee must resume annual performance tests;
- (b) Operation of a continuous monitoring system as described in 40 CFR 60.4345. The operating plan must be approved by SWCAA. The permittee shall submit a certification statement to SWCAA every six months that certifies that the quality assurance plan has been followed at all times or that exceptions have been reported. Any revision to the quality assurance plan must be reported with the semiannual report.; or
- (c) Continuous parameter monitoring as described in 40 CFR 60.4340(b)(ii) with a parameter monitoring plan as described in 40 CFR 60.4355. Superseded copies of the parameter monitoring plan must be maintained on site for a period of five years after the revision of the plan. The permittee shall submit a copy of the parameter monitoring plan to SWCAA or EPA upon request. The permittee shall submit a certification statement to SWCAA every six months that certifies that the parameter monitoring plan has been followed at all times or that exceptions have been reported. Any revision to the parameter monitoring plan must be reported with the semiannual report.

M2. Compliance Certification

WAC 173-401-615(1)

This monitoring requirement applies to Regs-2, 14, 15, 25 and 27.

The permittee shall certify the following in each semi-annual report:

(a) Only pipeline quality natural gas with a valid tariff sheet specifying that the total sulfur content is 20.0 grains of sulfur or less per 100 standard cubic feet is used as fuel for all permitted combustion units at the facility (excluding insignificant emission sources). Records of monitoring activities shall be maintained in accordance with Section VIII of this permit;

- (b) Installed equipment does not conceal or mask any emissions which are otherwise in violation of general standards; and
- (c) The height of the reciprocating engine and turbine stacks are not less than 84 feet above ground level or the stack heights are lower than 84 feet however modeling has been performed and approved by SWCAA that demonstrates compliance with all applicable regulations and standards at the lower stack height.

M3. Turbine Monitoring

ADP 05-2596, Condition 20

This monitoring requirement applies to Reg-3 and 21.

The turbine combustion temperature and gas producer speed shall be continuously monitored.

40 CFR 63.6640

M4. Emergency Generator Engine Hours Monitoring ADP 05-2596, Condition 22 This monitoring requirement applies to Requirements 4 and 5 for EU4.

The permittee shall install a non-resettable time totalizer to measure hours of operation of the emergency generator engine. The permittee shall record the hours of operation of the emergency generator engine once per month.

The Permittee shall document how many hours are spent for non-emergency, non maintenance, non readiness testing operation.

The Permittee shall have documentation onsite from the manufacturer, vendor or insurance company associated with the engine stating that maintenance checks and/or readiness testing is recommended.

Records of monitoring activities shall be maintained in accordance with Section VIII K1(d) of this permit.

M5. Fire Pump Engine Monitoring Plan 40 CFR 63.6625(e), 40 CFR 63.6655 This monitoring requirement applies to Requirements 6, 7, and 8 for EU5:

- a. The fire pump engine shall be operated and maintained in accordance with the manufacturer's emission-related operation and maintenance instructions or the Permittee's own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions
- b. The Permittee shall document and record each incidence of maintenance and repairs conducted to demonstrate compliance with the emissions-related maintenance requirements. Activities that must be documented include, but are not limited to: oil and oil filter changes, air cleaner inspections, and inspection of hoses and belts. (63.6655(e))

Records of monitoring activities shall be maintained in accordance with Section VIII K1(d) of this permit.

M6. Opacity Monitoring

WAC 173-401-615(1)

This monitoring requirement applies to Reqs-9, 17, 18 and 24.

The permittee shall perform monthly inspections of affected operations during daylight hours for the purpose of identifying potential visible emission violations. Whenever visible emissions are observed during the monthly inspection, or whenever visible emissions are indicated by a complaint, the permittee shall verify the equipment causing the emissions. The permittee shall within 60 minutes of observing visible emissions confirm whether the equipment involved is experiencing a malfunction and determine if all pollution control equipment is operating properly. If the equipment has an opacity limit higher than 0%, assure the equipment is operating within permitted limits using SWCAA Method 9 or EPA Method 9 as applicable to the emission unit. Within 24 hours of initial discovery, permittee shall resolve the visible emissions or excess emissions problem, or notify SWCAA by the next working day of progress made in resolving the operational problem. Implementation of corrective action does not relieve the permittee from the obligation of reporting permit deviations as specified in WAC 173-401-615(3). Records of monitoring activities shall be maintained in accordance with Section VIII of this permit.

M7. Fugitive Emissions Monitoring

WAC 173-401-615(1)

This monitoring requirement applies to Reqs-10, 11, 12 and 16.

This permittee shall record, and maintain record of, any air quality, odor or fallout related complaints received by the permittee or forwarded to the permittee by SWCAA regarding the compressor station property excluding noise or right-of-way issues. These complaints shall be investigated no later than one work day after the permittee has been notified. Investigation shall verify the validity of each complaint, the cause of emissions which prompted the complaint, and what, if any, corrective action was taken in response to the complaint.

In addition to complaint response, the permittee shall perform monthly inspections by performing a brief qualitative observation of any potential source of fugitive emissions including, but not limited to, dust and odors, etc. during daylight hours for the purpose of identifying excess fugitive emissions. If no fugitive emissions are observed, the permittee shall make a record as per Section VIII of this permit. Whenever any fugitive emissions are observed the permittee shall identify the source causing the emissions. The permittee shall within 60 minutes of discovery confirm whether the source involved is experiencing a malfunction, and whether reasonable precautions and good work practices are being employed to minimize emissions. Reasonable precautions and good work practices include, but are not limited to, worker training programs, closed doors and windows, vertical exhaust of ventilation equipment, and proper operation of ventilation systems. Implementation of corrective action does not relieve the permittee from the obligation of reporting permit deviations as specified in WAC 173-401-615(3). Records of monitoring activities shall be maintained in accordance with Section VIII of this permit.

M8. Complaint Monitoring

WAC 173-401-615(1)

This monitoring requirement applies to Req-13.

This permittee shall record, and maintain record of, any air quality, odor or fallout related complaints received by the permittee or forwarded to the permittee by SWCAA regarding the compressor station property excluding noise or right-of-way issues. These complaints shall be investigated no later than one work day after the permittee has been notified. Investigation shall verify the validity of each complaint, the cause of emissions which prompted the complaint, and what, if any, corrective action was taken in response to the complaint. Permittee shall take

appropriate corrective action for all valid complaints. Records of monitoring activities shall be maintained in accordance with Section VIII of this permit.

SWCAA 400-052, ADP 05-2596, Condition 23

M9. Reciprocating Engine Testing and Recording Requirements

This monitoring requirement applies to Regs-19 and 20.

The permittee shall test the reciprocating engine at least once every five years. If the engine has operated more than 5,000 hours since the last emission test, testing shall be performed during the next calendar year. Source testing shall be performed at two operating conditions, one of which must be representative of maximum intended operating conditions. The second load condition shall consist of a load (<85% torque and <218 rpm, <85% torque and ≥218 rpm, or ≥85% torque and <218 rpm) that the engine has most frequently operated at since the last source test or another load condition agreed upon by SWCAA. EPA Method 7E shall be used for NO_x. EPA Method 10 shall be used for CO and EPA Method 18 or 25A for VOCs. EPA Method 5 with back half condensable matter by Method 202, combined, or Method 17, or equivalent shall be used for PM. EPA Method 320, EPA Proposed Method 323 or equivalent as defined in Appendix A shall be used for formaldehyde. SWCAA Method 9 (SWCAA 400, Appendix A) for a minimum of 6 minutes shall be used for opacity.

The permittee shall record monthly hours of operation at each of the four load conditions (<85% torque and <218 rpm, <85% torque and <218 rpm, or $\geq85\%$ torque and <218 rpm).

The permittee shall continuously record rpm and torque while the unit is in operation. Compliance with the annual emission limits for NO_x, CO, VOCs, PM and formaldehyde shall be demonstrated by summing the hours of operation for each of the four load condition ranges (shown in R3(d)) and applying the corresponding emission rates in pounds per hour from the most recent source test data.

SO₂ compliance shall be determined based on the annual average sulfur content of the natural gas and a maximum heat input of 28.92 MMBtu per hour to obtain an emission factor as follows:

XX
$$\frac{\text{grains S}}{100 \text{ cf}}$$
 x 28.92 $\frac{\text{MMBtu}}{\text{hour}}$ x $\frac{\text{lb}}{7000 \text{ grains}}$ x $\frac{\text{cf}}{0.001 \text{ MMBtu}}$ x 2 $\frac{\text{lb SO}_2}{\text{lb S}}$ = X $\frac{\text{lb SO}_2}{\text{hour}}$

For benzene compliance shall be calculated using the emission factor in pounds per hour shown in the Technical Support Document (TSD) for ADP 05-2596 and actual hours of operation:

Pollutant Factor
Benzene 0.056 lb/hr

Records of monitoring activities shall be maintained in accordance with Section VIII of this permit.

M10. Turbine Testing and Recording Requirements ADP 05-2596, Condition 24
This monitoring requirement applies to Reqs-19 and 21.

The turbine shall be tested every five calendar years no later than the end of the month of December at one load point representing the maximum speed (>95% gas producer speed). More frequent NO_x

testing may be required by monitoring requirement M1 NO_x Standard. EPA Method 7E or 20 shall be used for NO_x. EPA Method 10 shall be used for CO and EPA Method 18 or 25A for VOCs. SWCAA Method 9 (SWCAA 400, Appendix A) for a minimum of 6 minutes shall be used for opacity.

The permittee shall record monthly hours of operation.

Compliance with the annual emission limits from the turbine shall be calculated using the most recent source test results at maximum load conditions in pounds per hour and actual hours of operation.

SO₂ compliance shall be determined based on the annual average sulfur content of the natural gas and a maximum heat input of 64.68 MMBtu per hour to obtain an emission factor as follows:

XX
$$\frac{\text{grains S}}{100 \text{ cf}}$$
 x 64.68 $\frac{\text{MMBtu}}{\text{hour}}$ x $\frac{\text{lb}}{7000 \text{ grains}}$ x $\frac{\text{cf}}{0.001 \text{ MMBtu}}$ x $2 \frac{\text{lb SO}_2}{\text{lb S}}$ = X $\frac{\text{lb SO}_2}{\text{hour}}$

For all other pollutants, annual emissions shall be calculated using the emission factor in pounds per hour contained in the TSD for ADP 05-2596 and actual hours of operation.

<u>Pollutant</u>	<u>Factor</u>
PM	0.43 lb/hr
Benzene	0.00046 lb/hr
Formaldehyde	0.25 lb/hr

Records of monitoring activities shall be maintained in accordance with Section VIII of this permit.

M11. Boiler and Generator Engine Recording Requirements ADP 05-2596, Conditions 4 & 5 This monitoring requirement applies to Reqs-19, 22, 23 and 28.

The permittee shall record hours of operation for the boiler and generator engine monthly.

Emissions for the boiler shall be calculated annually using annual hours of operation and the following emission factors from the TSD for ADP 05-2596:

Pollutant	<u>Factor</u>	
NO_x	0.245 lb/hr	
CO	0.206 lb/hr	
VOC	0.014 lb/hr	
SO_2	0.009 lb/hr	
PM	0.019 lb/hr	

Emissions for the emergency generator engine shall be calculated annually using annual hours of operation and the following emission factors from the TSD for ADP 05-2596:

Pollutant	<u>Factor</u>	
NO_x	10.2 lb/hr	
CO	17.2 lb/hr	

NORTHWEST PIPELINE GP

VOC	0.14 lb/hr	
SO_2	0.016 lb/hr	
PM	0.090 lb/hr	

Records of monitoring activities shall be maintained in accordance with Section VIII of this permit.

M12. Reciprocating Engine RPM and Torque

ADP 05-2596, Condition 17

This monitoring requirement applies to Req-26.

The rpm and torque shall be continuously monitored and recorded during normal operation. The data shall be reported based on hourly averages. Records of monitoring activities shall be maintained in accordance with Section VIII of this permit.

M13. Boiler Emissions Monitoring

40 CFR 63 Section 7540

This monitoring requirement applies to Req-22.

The Permittee shall conduct a tune-up of the Sellers natural gas boiler every five years as specified in §63.7540. Each 5-year tune-up must be conducted no more than 61 months after the previous tune-up.

[§63.7540(a)(12) to Subpart DDDDD of 40 CFR 63]

Records of monitoring results shall be maintained in accordance with Section VIII of this permit.

VIII. RECORDKEEPING TERMS AND CONDITIONS

The permittee shall maintain files of all information, including all reports and notifications, recorded in a form suitable and readily available for expeditious inspection and review. The files shall be retained for at least five years following the date of each occurrence, measurement, maintenance, corrective action, report, or record. The recordkeeping requirements listed below do not apply to insignificant emission units (IEUs) pursuant to WAC 173-401-530(2)(c).

K1. General Recordkeeping ADP 05-2596, Conditions 14-16, WAC 173-401-615(2)

Permittee is required to keep the following records as applicable:

- (a) Inspections & certifications
 - (1) Date and time of the inspection or certification;
 - (2) Name and title of the person who conducted the inspection or certification;
 - (3) Identification of the unit or activity being inspected or certified;
 - (4) Operating conditions of the unit or the type of activity occurring at the time of the inspection or certification;
 - (5) Compliance status of each monitored requirement as described in Sections V and VII of this Permit; and
 - (6) Description of corrective action (if any) taken in response to a discovered permit deviation, excess emission, upset condition, or malfunction, as applicable.

(b) Complaints

- (1) Date and time of complaint;
- (2) Name of the complainant;
- (3) The nature of the complaint;
- (4) Date and time of follow-up inspection;
- (5) The name and title of the person who conducted the inspection or certification; and
- (6) Description of corrective action (if any) taken in response to complaint.

(c) Sampling and testing

- (1) The date sampling was performed;
- (2) The entity that performed the sampling;
- (3) The analytical techniques used to take the sample;
- (4) The operating conditions existing at the time of sampling or measurement;
- (5) The date analyses were performed;
- (6) The entity that performed the analyses;
- (7) The analytical techniques or methods used;
- (8) The results of such analyses;
- (9) Compliance status of each monitored requirement as described in Section V and VII of this permit; and
- (10) Corrective action taken in response to permit deviations and when action was initiated.

(d) Maintenance Activities

- (1) Date and time of the maintenance activity;
- (2) Name of the person who performed the maintenance;
- (3) Identification of the unit or activity being maintained; and
- (4) Description of the maintenance being conducted.

- (e) Excess Emissions and Upset Conditions
 - (1) Date and time of excess emission or upset condition occurred;
 - (2) Nature of the excess emission or upset condition and an identification of the affected unit, process, or activity; and
 - (3) Description of corrective action taken in response to a discovered permit deviation, excess emission, upset condition, or malfunction, as applicable.
- (f) Periodic Monitoring and Emissions Records
 - (1) Date and time of parameter observation or emission calculation;
 - (2) Name of parameter observed or emission calculated;
 - (3) Observed parameter value or calculated emission value with appropriate units; and
 - (4) Periods that data was unavailable.

K2. Boiler Recordkeeping

40 CFR 63 Section 7555, 7560

Required boiler records must be in a form suitable and readily available for expeditious review and must be retained for a minimum of five years following the date of each occurrence, measurement, maintenance, corrective action, report or record. These records include those required in Table 8 to Subpart DDDDD required to show continuous compliance. Boiler records must be kept on-site, or they must be accessible from on-site, for at least two years after the date of each occurrence, measurement, maintenance, corrective action, report, or record. The remaining three years of data may be retained off site. Such files may be maintained on an SD/USB drive ("thumb drive" or flash memory card), external hard drive, on compact disk(s), on magnetic tape disks, or on microfiche. The following compliance records are required for boilers at the facility as specified:

(a) **Record of Notifications:** A copy of each notification and report submitted to comply with Subpart DDDDD, including all documentation supporting any Initial Notification or Notification of Compliance Status or semiannual compliance report. The initial notification was submitted to EPA May 29, 2013.

IX. REPORTING TERMS AND CONDITIONS

All required reports must be certified by a responsible official consistent with WAC 173-401-520. Certification shall state that, based on information and belief formed after reasonable inquiry, the statements and information contained in the submittal are true, accurate, and complete. Where an applicable requirement requires reporting more frequently than once every six months, the responsible official's certification need only be submitted once every six months, covering all required reporting since the date of the last certification.

Where a reporting schedule is specified (e.g. quarterly, semi-annual, or annual), compliance with the reporting frequency is met when reports are submitted more frequently than required.

Addresses of regulatory agencies are the following, unless otherwise instructed:

Southwest Clean Air Agency 11815 NE 99th Street, Suite 1294 Vancouver, WA 98682-2322 Part 70 Air Operating Permits U.S. EPA Region 10, Mail Stop: OAW-150 1200 Sixth Avenue, Suite 155 Seattle, WA 98101

> 40 CFR 60.7(b) WAC 173-401-615(3)(b) SWCAA 400-107, SWCAA 400-115 ADP 05-2596 Conditions 26 and 27

R1. Deviations from Permit Conditions

The permittee shall report deviations from permit requirements no later than 30 days after the end of the month during which the deviation is discovered. Deviations that represent a potential threat to human health or safety shall be reported as soon as possible but no later than 12 hours after the deviation is discovered. Excess emissions shall be reported as soon as possible. In accordance with SWCAA 400-107(1), excess emissions that the permittee wishes to be considered unavoidable must be reported as soon as possible, but no later than 48 hours after discovery.

All deviation reports shall be submitted in writing (e.g. e-mail, facsimile or letter). Each report shall include the following information:

- (a) Identification of the emission unit(s) involved;
- (b) Duration of the event including the beginning and end times; and
- (c) Description of the event, including:
 - (1) Whether or not the deviation was due to an upset condition;
 - (2) Probable cause of the deviations; and
 - (3) Description of corrective action taken in response to the event (if any).

Excess emissions shall be reported as soon as possible. In accordance with SWCAA 400-107(1), excess emissions that the Permittee wishes to be considered unavoidable must be reported as soon as possible, but no later than 48 hours after discovery. The Permittee shall report the upset condition by telephone, e-mail or facsimile as initial notification to SWCAA; a message may be left on the answering machine for conditions outside of normal business hours.

R2. Complaint Reports

WAC 173-401-615(3)

The permittee shall report all complaints to SWCAA within three business days of receipt. Complaint reports shall include the following information:

(a) Date and time of the complaint;

- (b) Name of the complainant;
- (c) Nature of the complaint; and
- (d) Description of corrective action taken in response to complaint (if any).

WAC 173-401-615(3)

R3. Semi-annual Reports

ADP 05-2596 Condition 25

The permittee shall submit to SWCAA by September 15th and March 15th of the following year for the six month periods January through June and July through December, respectively, the following information:

- (a) A report on the status of all monitoring requirements of this permit, consistent with WAC 173-401-615(3). Any deviation from permit requirements shall be clearly identified.
- (b) Certification of any reports submitted during the semi-annual period that have not already been certified consistent with the provisions of WAC 173-401-520.
- (c) The permittee shall certify in each semi-annual report that only pipeline quality natural gas with a valid tariff sheet specifying that the total sulfur content is 20 grains of sulfur or less per 100 standard cubic feet is used as fuel for all permitted combustion units at the facility (excluding insignificant emission sources).
- (d) The permittee shall certify in each semi-annual report that either:
 - (1) The height of the reciprocating engine and turbine stacks are not less than 84 feet above ground level; or
 - (2) The stack heights are lower than 84 feet, however modeling has been performed and approved by SWCAA that demonstrates compliance with all applicable regulations and standards at the lower stack height.
- (e) If permittee opts to demonstrate compliance with the NO_x standard contained in 40 CFR 60.4320(a) by operation of a continuous monitoring system as described in 40 CFR 60.4345. The permittee shall submit a certification statement to SWCAA every six months that certifies that the quality assurance monitoring plan has been followed at all times or that exceptions have been reported. Any revision to the parameter monitoring plan must be reported with the semiannual report.
- (f) If permittee opts to demonstrate compliance with the NO_x standard contained in 40 CFR 60.4320(a) by operation of a parameter monitoring plan as described in 40 CFR 60.4355. The permittee shall submit a certification statement to SWCAA every six months that certifies that the parameter monitoring plan has been followed at all times or that exceptions have been reported. Any revision to the parameter monitoring plan must be reported with the semiannual report.
- (g) Total hours of reciprocating engine operation at the nearest to the following four loads and conditions:

Load	Torque(%)	<u>RPM</u>
1	<85	<218
2	<85	≥218
3	≥85	<218
4	≥85	≥218

- (h) Hours of operation for the turbine including both hours of operation in low NO_x mode and not in low NO_x mode.
- (i) The total hours of operation of the boiler and total hours of operation of the generator engine.

- (j) Hours of monitoring downtime for which the low NO_x operating status of the turbine cannot be determined.
- (k) Air emissions for the reciprocating engine, turbine, boiler, generator engine and fire pump engine.

R4. Annual Compliance Certification WAC 173-401-630(5), 40 CFR 60.11(g)

The permittee shall submit to SWCAA and EPA certification of compliance with all terms and conditions of this permit in accordance with WAC 173-401-630(5)(d) for the period from January 1 to December 31 by April 15th of the following year. The certification shall include:

- (a) Identification of each term or condition of the permit that is the basis of the certification;
- (b) The compliance status;
- (c) Whether compliance was continuous or intermittent; and
- (d) The method(s) used to determine the compliance status.

When the permittee submits compliance certification for EU2 all credible evidence must be considered as in accordance with 40 CFR 60.11(g).

R5. Emission Inventory Reports SWCAA 400-105, ADP 05-2596 Condition 25

The permittee shall submit an inventory of annual emissions from the source each year to SWCAA by March 15th of the following year in accordance with SWCAA 400-105, unless an alternate date is approved by SWCAA. The inventory shall include emissions of NO_x, SO₂, CO, VOCs, PM, HAPs and TAPs. Annual emissions shall be calculated consistent with the TSD for ADP 05-2596.

WAC 173-401-615(3)

R6. Source Test Reports

SWCAA 400-106, ADP 05-2596 Condition 28

A final emission test report shall be prepared and submitted to SWCAA within 45 calendar days of test completion and, at a minimum, shall contain the following information.

- (a) Description of the source including manufacturer, model number and design capacity of the equipment, and the location of the sample ports or test locations,
- (b) Time and date of the test and identification and qualifications of the personnel involved,
- (c) Summary of results, reported in units and averaging periods consistent with the application emissions standard or unit,
- (d) Summary of control system or equipment operating conditions,
- (e) Summary of production related parameters,
- (f) A description of the test methods or procedures used including all field data, quality assurance/quality control procedures and documentation,
- (g) A description of the analytical procedures used including all laboratory data, quality assurance/quality control procedures and documentation,
- (h) Copies of field data and example calculations,
- (i) Chain of custody information,
- (j) Calibration documentation,
- (k) Discussion of any abnormalities associated with the results, and
- (l) A statement signed by the senior management official of the testing firm certifying the validity of the source test report.

X. NON-APPLICABLE TERMS AND CONDITIONS

WAC 173-401-640(2)

The following lists all federal, state, and/or local requirements that might reasonably apply to the permittee, but are deemed nonapplicable after review by SWCAA. In accordance with WAC 173-401-640, the permittee is provided a permit shield for not complying with the requirements listed below where they have been identified to be non-applicable to specific emission units.

1. Registration program

WAC 173-400-099, SWCAA 400-100(2)

The permittee is an air operating permit source. Pursuant to WAC 173-400-101(7), air operating permit sources are exempt from the registration program established under WAC 173-400-099, and implemented in accordance with WAC 173-400-100 through WAC 173-400-104. Pursuant to SWCAA 400-100(1)(b) air operating permit sources are exempt from the registration requirements of SWCAA 400-100.

2. Stationary Combustion Turbine MACT (Subpart YYYY)

40 CFR 63.6080

Subpart YYYY establishes HAP limits, testing, monitoring, recordkeeping and reporting requirements for turbines located at major HAP facilities. Lean premix gas-fired stationary combustion turbines constructed after January 14, 2003 must limit formaldehyde emissions to less than 91 ppbvd at 15% O₂. This facility is a major HAP facility. However, on August 18, 2004 EPA stayed the effectiveness of two subcategories: lean premix gas-fired turbines and diffusion flame gas-fired turbines. The turbine at this facility is a lean premix gas-fired turbine therefore it is not subject to this subpart.

3. Stationary Gas Turbine NSPS (Subpart GG)

40 CFR 60.330

Subpart GG applies to each turbine with a heat input at peak load greater than or equal to 10.7 gigajoules per hour (10 MMBtu/hour) that was installed or modified after October 3, 1982. The turbine was installed in 2006 and has a heat input of 64.7 MMBtu/hour. However, the turbine is subject to 40 CFR Part 60.4300 et seq. (Subpart KKKK), and is therefore not subject to this subpart.

4. Chemical Accident Prevention Provision

40 CFR 68

40 CFR 68 "Chemical Accident Prevention Provision" does not apply to Northwest Pipeline's compressor stations because the compressor stations do not meet the definition of "stationary source". Under 40 CFR 68 Subpart A, definitions, the regulations state under the term "Stationary Source" the following:"...The term stationary source does not apply to transportation, including storage incident to transportation, of any regulated substance or any other extremely hazardous substance under the provisions of this part. ...Transportation includes, but is not limited to, transportation subject to oversight or regulation under 49 CFR parts 192, 194, 195, or a state natural gas or hazardous liquid program for which the state has in effect a certification to DOT under 49 U.S.C. section 60105..." Northwest Pipeline is a natural gas transmission company, is currently regulated under 49 CFR part 192 and thus is not required to submit a risk management plan.

5. National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

40 CFR 63.6650

Subpart ZZZZ applies to stationary reciprocating internal combustion engines (RICE) located at major and area sources of HAP emissions. Engine EU1 is an existing 2 stroke lean burn stationary RICE with a site rating of more than 500 hp located at a major source of HAP emissions and does not have to meet any requirements of this subpart and subpart A, including initial notification (40 CFR 63.6590(b)(3). Subpart ZZZZ is applicable to EU4, the emergency generator engine, and EU5, the fire pump engine.

6. MACT Records – Boiler MACT (Subpart DDDDD)

40 CFR 63.7545

Initial Notifications: The Permittee must submit to the Administrator an initial notification when a boiler becomes subject to 40 CFR 63 Subpart DDDDD in accordance with §63.9(b), postmarked or delivered within 15 calendar days from the date of actual startup of the boiler. The initial notification was submitted May 29, 2013.

Energy Assessment: The Permittee shall conduct a one-time energy assessment on the Sellers natural gas boiler performed by a qualified energy assessor that meets the requirements for energy assessments in Table 3 to Subpart DDDDD of Part 63. The Permittee shall have the opportunity to take credit for implementing energy conservation measures identified in the energy assessment in accordance with §63.7533. This assessment was performed October 2015.

APPENDIX A - EQUIVALENT SOURCE TEST METHOD

Permittee may use an alternate source test method for formaldehyde testing provided the accuracy of the alternate test method has been demonstrated as follows:

- 1. Accuracy shall be verified by performing simultaneous tests of both EPA Method 320 and the alternate test method.
- 2. The testing shall consist of a minimum of three 60 minute test runs.
- 3. The testing shall be performed on a two cycle reciprocating engine equipped with CleanBurnTM technology rated between 2,000 and 10,000 horsepower.
- 4. The results of each of the three test runs shall agree within 20%.